


15-09-2022

OJ-Air2Master

Modbus and BACnet protocol

Software version 6.54



Quick overview

The most common used parameters.

Modbus Info

General information about modbus RTU/TCP-IP

Modbus RTU Connection

How to connect Modbus RTU (RS-485)

BACnet Info

General information about BACnet TCP-IP

BACnet Connection

How to connect BACnet TCP-IP

Parameters

Complete list of all modbus and BACnet parameters.

BACnet CONFORMANCE CERTIFICATE



No. BTL-30207

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the BTL Testing Policies, see Test Report number VG 2016_12897 of MBS.

Product name (B-AAC)
OJ-Air2
Model(s)* OJ-Air2Master, x-Air2Master, EX-Master
Software version
1.2
Vendor
OJ Electronics A/S
Stenager 13B
6400 Sønderborg, Denmark


* where x is according to listing information

This certificate is valid until **31-Mar-2023**.

06-Nov-2017
Date of Initial Certification


Dipl.-Ing. G. Weinmann
Head of Certification Body

BACnet/Modbus overview



	BacNet	Modbus
Actual operating mode	AI 0	3x0001
Operation ON/OFF	BI 0	1x0001
Extended low speed -> Active	BI 3	1x0004
Extended high speed -> Active	BI 4	1x0005
Alarm relay 1 (A-alarm)	BI 30	1x0035
Alarm relay 2 (B-alarm)	BI 31	1x0036
Alarm reset signal (AutoReturn to zero)	BV 0	0x0001

AI= Analog Input
 AV= Analog Value
 BI= Binary Input
 BV= Binary Value

	BacNet	Modbus
1 Actual exhaust temp. [1/100°C]	AI 22	3x0026
Actual extract flow [l/s]	AI 7	3x0009
Extract motor output percentage [1/100%]	AI 60	3x0083
Setpoint for extract flow, low speed [l/s]	AV 12	4x0014
Setpoint for extract flow, medium speed [l/s]	AV 254	4x0321
Setpoint for extract flow, high speed [l/s]	AV 13	4x0015
2 Rot. heat exchanger – output percent. [%]	AI 73	3x0097
3 Actual outdoor temp. [1/100°C]	AI 20	3x0024
Inlet filter pressure [Pa]	AI 27	3x0031
Inlet filter monitor max. alarm limit [Pa]	AI 31	3x0039
4 Extract filter pressure [Pa]	AI 28	3x0032
Max. alarm limit, extract filter pressure drop [Pa]	AI 32	3x0040
5 Actual inlet flow [l/s]	AI 5	3x0007
Inlet motor output percentage [1/100%]	AI 51	3x0073
Setpoint for inlet flow, low speed [l/s]	AV 10	4x0011
Setpoint for inlet flow, medium speed [l/s]	AV 251	4x0320
Setpoint for inlet flow, high speed [l/s]	AV 11	4x0012
6 Actual room temperature [1/100 °C]	AI 21	3x0025
Actual extract duct pressure [Pa]	AI 3	3x0005
Setpoint for duct pressure, extract, low speed [Pa]	AV 6	4x0007
Setpoint for duct pressure, extract, medium speed [Pa]	AV 255	4x0323
Setpoint for duct pressure, extract, high speed [Pa]	AV 7	4x0008
7 Actual inlet temperature [1/100°C]	AI 16	3x0020
Control type setting	AV 133	4x0148
Temperature setpoint for actual control type	AV 134	4x0149
Min. limit, inlet temp. [1/100°C]	AV 135	4x0150
Max. limit, inlet temp. [1/100°C]	AV 136	4x0151
Actual heating power [1/100%]	AI 36	3x0054
Heating relay 1	BI 26	1x0031
Act. heating bat. temp.[1/100°C]	AI 26	3x0030
Actual cooling power [1/100%]	AI 38	3x0056
Actual inlet duct pressure [Pa]	AI 1	3x0003
Setpoint for duct pressure, inlet, low speed [Pa]	AV 2	4x0003
Setpoint for duct pressure, inlet, medium speed [Pa]	AV 252	4x0322
Setpoint for duct pressure, inlet, high speed [Pa]	AV 3	4x0004

Modbus RTU/TCP

OJ Air2, Program version 6.30 and later versions

Overview

This Protocol contains all Modbus addresses and registers in the OJ-Air2Master. Updating of values in the individual registers is dependent on the actual configuration of the air handling unit. It will, for example, be possible to read out water heating coil temperature register 3x0030 irrespective of whether or not an water heating coil is installed in the system concerned.

The value will, however, only be used if the associated temperature sensor is installed. Modbus can access single addresses or several addresses simultaneously, either reading or writing 1-bit or 16-bit values.

A Modbus address contains either a 1-bit value or a 16-bit integer.

Communication

TCP/IP: 1 x 10/100 Mbit Ethernet, RJ45 connector.

Modbus RS485: 1 x external Modbus, RS485, RJ12 connector, which can be set for 9.6 kBd, 19.2 kBd or 38.4 kBd.

Pin1 NC, Pin2 GND, Pin3 RS485 B, Pin4 RS485 A, Pin5 NC, Pin6 GND (see fig. 2).

Hand terminal: 1 x Modbus, RS485, 115 kBd, +24 V DC, RJ12 connector.

RS485 A: Not in use

RS485 B & C: 2 x shared local Modbus, RS485, 38.4 kBd, +24 V DC, RJ12 connector.

Standard Modbus TCP/IP kommunikationsport: 502

Modbus data format

Modbus data types are 1-bit values and 16-bit values.

Modbus Type	Description	Reference
Coil Status (R/W)	Discrete Output	0x
Input Status (R)	Discrete Input	1x
Holding Register (R/W)	16-bit Output Register	4x
Input register (R)	16-bit Input Register	3x

R = Read Only

R/W = Read / Write

Supported Modbus commands

OJ Air2 supports the following Modbus commands:

Function code	Description
1	Read Coil Status
2	Read Input Status
3	Read Holding Registers
4	Read Input Registers
5	Force Single Coil
6	Preset Single Registers
8	Diagnostics. Sub-function 00 Only - Return Query Data (loop back)
15	Force Multiple Coils
16	Preset Multiple Registers

OJ Air2 Master Controller RJ12 Modbus/RTU connection

Fig. 1 OJ Air Master, Connector diagram, visual topside down




Fig. 2 Configuration for communication via external Modbus

OJ-Air2 basic training SW6.10 - EN



Communication via external Modbus RTU / RS485





Fig. 3 Modbus RS485 - RJ12 socket



BACnet

OJ Air2, Program version 4.18 and subsequent versions.

Overview

BACnet features enable BACnet control and monitoring of a complete

Air Handling Unit (AHU), which is equipped with an OJ-Air2Master controller.

The BACnet functionality is implemented in OJ-Air2Masters with software version 2.00 or higher.

This protocol contains all BACnet addresses and registers in the OJ-Air2 Master. Updating of values in the individual registers is dependent on the actual configuration of the air handling unit. It will, for example, be possible to read out water heating coil temperature Analog Input Object Instance 26 irrespective of whether or not a water heating coil is installed in the system concerned.

The value will, however, only be used if the associated temperature sensor is installed.

The OJ-Air2Master is a BACnet Advanced Application Controller (B-AAC)

Supported Data Link Layer Options: BACnet IP

Please also see the documents "OJ-Air2 BACnet PICS" (Protocol Implementation Conformance Statement)

and "OJ-Air2 EDE" (Engineering Data Exchange).

Communication

BACnet TCP/IP: 1 pcs. 10/100Mbit Ethernet, RJ45 socket

Standard BACnet TCP/IP communication port: 47808

Object Identifier:

The Object_Identifier is automatic set to the last 5 digits in the OJ-Air2Master IP adress.

- Samples: IP-adresse = 172.21.0.95 Object Identifier = 95
- IP-adresse = 155.37.0.216 Object Identifier = 216
- IP-adresse = 155.37.35.123 Object Identifier = 35123
- IP-adresse = 132.65.124.103 Object Identifier = 24103
- IP-adresse = 172.20.211.47 Object Identifier = 11047
- IP-adresse = 155.37.111.123 Object Identifier = 11123
- IP-adresse = 168.25.111.1 Object Identifier = 11001

OBS! The Object_Identifier will only be set once and only when the OJ-Air2 Master is powered up or restarted

Max. 300 values can at the same time be registered to the COV (Change Of Value)

BACnet Interoperability Building Blocks Supported


Data Sharing	DS-RP-B	Data Sharing-Read Property-B
Data sharing	DS-WP-B	Data Sharing-Write Property-B
Device Management	DM-DDB-B	Device Management-Dynamic Device Binding-B
Device Management	DM-DOB-B	Device Management-Dynamic Object Binding-B
Device Management	DM-DCC-B	Device Management-Dynamic Communication Control-B

Standard Object Types Supported

Object type	Properties
Analog Input	Object_Identifier, Object_Name, Object_Type, Present_Value, Status_Flags, Event_State, Out_Of_Service, Units, Min_Pres_Value, Max_Pres_Value, Resolution, Reliability, COV_Increment
Analog Value	Object_Identifier, Object_Name, Object_Type, Present_Value, Status_Flags, Event_State, Out_Of_Service, Units, Priority_Array, Relinquish_Default, COV_Increment.
Binary Input	Object_Identifier, Object_Name, Object_Type, Present_Value, Status_Flags, Event_State, Out_Of_Service, Polarity.
Binary Value	Object_Identifier, Object_Name, Object_Type, Present_Value, Status_Flags, Event_State, Out_Of_Service, Priority_Array, Relinquish_Default.
Device	Object_Identifier, Object_Name, Object_Type, System_Status, Vendor_Name, Vendor_Identifier, Model_Name, Firmware_Revision, Application_Software_Version, Location, Description, Protocol_Version, Protocol_Revision, Protocol_Services_Supported, Protocol_Object_Types_Supported, Object_List_Max_APDU_Length_Accepted, Segmentation_Supported, APDU_Timeout, Number_Of_APDU_Retries, Device_Address_Binding, Database_Revision.

OJ Air2 Master Controller
1 x RJ45 TCP/IP for BACnet/IP forbindelse for internal BACnet-server in OJ Air2 Master

Fig. 1 OJ Air Master, Connector diagram, visual topside down



Component	Function	Standard/ Special	Name	SI Unit	Modbus register	SW vers.	BacNet parameter Binary value (R/W)	SW vers.	Min	Max	Factory settings	English			
1. Info															
AHU controller	Alarm	Standard	Air_Reset		0x0001	x.xx	BV0	x.xx	0	1		Alarm reset signal (AutoReturn to zero)			
Heat exchanger	Coil recovery	Standard	CoilRecovFunc		0x0002	x.xx	BV1	x.xx	0	1	0	Cooling recovery: ON/OFF			
AHU controller	Summer Night Cooling	Standard	SN_Func		0x0003	x.xx	BV2	x.xx	0	1	0	Summer night cooling: ON/OFF			
AHU controller	Summer/Winter comp.	Standard	SWTC_Func		0x0004	x.xx	BV3	x.xx	0	1	0	Summer/winter temp. compensation: ON/OFF			
Fan	Outdoor temp. comp.	Standard	FlwTmpCmpFunc		0x0005	x.xx	BV4	x.xx	0	1	0	Flow/outdoor temperature compensation: ON/OFF			
Damper, Recirculation	Recirculation heat	Standard	RecircFunc		0x0006	x.xx	BV5	x.xx	0	1	0	Recirculation: ON/OFF (*1 = Open damper)			
Fan	Forced cooling	Standard	CoilFwForceFc		0x0007	x.xx	BV6	x.xx	0	1	0	Forced flow with cooling demand: ON/OFF			
AHU controller	Summer/winter time	Standard	TimeSw_SumFunc		0x0008	x.xx	BV7	x.xx	0	1	1	Automatic summer/winter time: ON/OFF			
Fan	Speed	Standard	ExtDrfHlPeriod		0x0009	x.xx	BV8	x.xx	0	1	0	Input for forced high speed			
Fan	Speed	Standard	ExtDrfHlPeriodON		0x0010	x.xx	BV9	x.xx	0	1	0	Run-on time for forced high speed active			
Heat exchanger drive	Speed	Standard	EXC_CCv		0x0011	x.xx	BV26	6.41	0	1	0	Rotary heatexchanger, turn rotation direction to counter clock wise (CCW)			
Fan	Speed	Standard	ExtDrfMePeriod		0x0012	x.xx	NA	NA	0	1	0	Input for forced medium speed			
AHU controller	Summer Night Cooling	Standard	SN_FuncLoSpeed		0x0013	6.41	BV27	6.51	0	1	0	Summer Night Cooling activated in low speed			
AHU controller	Speed	Standard	ExtHighSpdSet		0x0014	6.51	BV28	6.51	0	1	0	External high speed start signal			
Pressure	Calibration	Standard	ManZeroCall		0x0020	x.xx	BV10	4.18	0	1	0	Start manual zero calibration (can be used together with automatic zero calibration)			
Pressure	Calibration	Standard	AutoZeroCall		0x0021	x.xx	BV11	4.18	0	1	0	Is automatically reset to zero (OFF) once calibration has been completed			
												0	Automatic zero calibration: ON/OFF		
													Dynamic filter alarm -> ON/OFF		
													0	OFF -> static alarm limit (constant)	
														ON -> dynamic alarm limit (limit based on flow)	
														Start filter calibration. Is automatically reset to zero (OFF) once calibration has been completed.	
														NOTE! ONLY IF "DYNAMIC MODE" IS SET	
														Filter calibration completed (valid filter data)	
														NOTE! ONLY IF "DYNAMIC MODE" IS SET	
														0	Enable combi coil for control via external Modbus [1=Modbus/0=Dig. input]
														1	Hot water supply is available for the combi coil
														1	Cold water supply is available for the combi coil
														0	Activate outdoor temperature from BMS
														0	Activate room temperature from BMS
														0	Force recirc via Ext. Modbus (*1 = Open damper)
														0	Enable Modbus Force recirc signal
														0	Filter (OA) Dynamic Alarm function ON/OFF OFF -> Static AlarmLimit (Const) ON -> Dynamic AlarmLimit (Limit based on flow)
														0	Filter (SA) Dynamic Alarm function ON/OFF OFF -> Static AlarmLimit (Const) ON -> Dynamic AlarmLimit (Limit based on flow)
														0	Filter (EX) Dynamic Alarm function ON/OFF OFF -> Static AlarmLimit (Const) ON -> Dynamic AlarmLimit (Limit based on flow)
														0	Filter (EX1) Dynamic Alarm function ON/OFF OFF -> Static AlarmLimit (Const) ON -> Dynamic AlarmLimit (Limit based on flow)
1. Info															
AHU controller	Speed	Standard	Operation		1x0001	x.xx	B10	x.xx	0	1		Operation ON/OFF			
AHU controller	Speed	Standard	ExtStop		1x0002	x.xx	B11	x.xx	0	1		External stop			
AHU controller	Speed	Standard	ExtHlSpeed		1x0003	x.xx	B12	x.xx	0	1		External high speed			
AHU controller	Speed	Standard	ExtDrfLoSpeed		1x0004	x.xx	B13	x.xx	0	1		Extended low speed -> Active			
AHU controller	Speed	Standard	ExtDrfHlSpeed		1x0005	x.xx	B14	x.xx	0	1		Extended high speed -> Active			
AHU controller	Fire	Standard	ExtBrndStop		1x0006	x.xx	B178	x.xx	0	1		Status Brandstop input			
Fan	Speed	Standard	ExtDrfMeSpeed		1x0007	x.xx	B1225	x.xx	0	1		Extended medium speed -> Active			
Heating coil, Electric	Status	Standard	ElBattPowerRed		1x0010	x.xx	B15	x.xx	0	1		Power to electric heating coil reduced due to low flow			
AHU controller	Summer Night Cooling	Standard	SN_Drift		1x0011	x.xx	B16	x.xx	0	1		Summer night cooling is active			
AHU controller	Summer Night Cooling	Standard	SN_Reset		1x0012	x.xx	B17	x.xx	0	1		Reset parameters for summer night cooling (new calculation is initiated)			
AHU controller	Summer/Winter comp.	Standard	SWTC_WintComp		1x0013	x.xx	B18	x.xx	0	1		Winter temperature compensation is active			
AHU controller	Summer/Winter comp.	Standard	SWTC_SumComp		1x0014	x.xx	B19	x.xx	0	1		Summer temperature compensation is active			
AHU controller	Summer/Winter comp.	Standard	SW_Status		1x0015	x.xx	B10	x.xx	0	1		Summer/winter actual status			
														OFF -> winter operation (*0)	
														ON -> summer operation (*1)	
Damper, Recirculation	Recirculation heat	Standard	RecircStatus		1x0016	x.xx	B111	x.xx	0	1		Recirculation status (*1 = Open damper)			
Heat exchanger	Speed	Standard	EXC_Exercise		1x0017	x.xx	B112	x.xx	0	1		Exercising heat exchanger -> Active			
Heat exchanger	Status	Standard	CExIceProtect		1x0018	x.xx	B113	x.xx	0	1		Signal to cross-flow exchanger reduced (frost protection)			
Fan	Status	Standard	SupDuctMinFlow		1x0019	x.xx	B114	x.xx	0	1		Supply duct pressure controller reduced to min. flow			
Fan	Status	Standard	SupDuctMaxFlow		1x0020	x.xx	B115	x.xx	0	1		Supply duct pressure controller increased to max. flow			
Fan	Status	Standard	ExtDuctMinFlow		1x0021	x.xx	B116	x.xx	0	1		Extract duct pressure controller reduced to min. flow			
Fan	Status	Standard	ExtDuctMaxFlow		1x0022	x.xx	B117	x.xx	0	1		Extract duct pressure controller increased to max. flow			
Heat exchanger	Status	Standard	CoolRecovery		1x0023	x.xx	B18	x.xx	0	1		Cooling recovery -> status			
Heating coil 1, Water	Status	Standard	HW1FrosReg		1x0024	x.xx	B119	x.xx	0	1		Circulation pump on heating coil: Frost protection -> Active			
Heating coil 1, Water	Status	Standard	HW1PumpExer		1x0025	x.xx	B120	x.xx	0	1		Circulation pump on heating coil: Pump exercising -> Active			
Cooling coil	Status	Standard	CW_PumpExer		1x0026	4.18	B121	4.18	0	1		CoolWaterCoil PumpExercise active			
Heating coil 1, Electric	Status	Standard	Heat_FlwdnReq		1x0027	x.xx	B122	x.xx	0	1		Signal to heating coil reduced (insufficient flow) -> Active			
AHU controller	Status	Standard	TempRegMinSup		1x0028	x.xx	B123	x.xx	0	1		*1 when min. supply temperature control is active.			
														Only active when TempRegMode is 1 or 2 (room temp. control)	
AHU controller	Status	Standard	TempRegMaxSup		1x0029	x.xx	B124	x.xx	0	1		*1 when max. supply temperature control is active.			
														Only active when TempRegMode is 1 or 2 (room temp. control)	
Heat exchanger	Status	Standard	BattEXC_Exer		1x0030	x.xx	B125	x.xx	0	1		Circulation pump on heat recovery coil: Pump exercising -> Active			
Heating coil 1	Status	Standard	Heat_RE1		1x0031	x.xx	B126	x.xx	0	1		Heating relay 1			
Cooling coil 1	Status	Standard	Cool_RE1		1x0032	x.xx	B127	x.xx	0	1		Cooling relay 1			
Heat exchanger	Status	Standard	BattEXC_PumpRE		1x0033	x.xx	B128	x.xx	0	1		Circulation pump on heat recovery coil: Pump -> Running			
AHU controller	Alarm	Standard	AirActive		1x0034	x.xx	B129	x.xx	0	1		At least one active alarm			
AHU controller	Alarm	Standard	Air_RE1		1x0035	x.xx	B130	x.xx	0	1		Alarm relay 1 (A-alarm)			
AHU controller	Alarm	Standard	Air_RE2		1x0036	x.xx	B131	x.xx	0	1		Alarm relay 2 (B-alarm)			
AHU controller	Fire	Standard	Air_FireSignal		1x0037	x.xx	B132	x.xx	0	1		Fire alarm signal (room sensor)			
AHU controller	Smoke	Standard	Air_SmokeSig		1x0038	x.xx	B133	x.xx	0	1		Smoke/fire alarm signal (duct sensor)			
Heating coil, Electric	Alarm	Standard	EL1_OverHtBac		1x0039	x.xx	B1219	x.xx	0	1		Electric coil: High temperature alarm signal			
Heating coil, Electric	Alarm	Standard	AirElBattCont		1x0040	x.xx	B1220	x.xx	0	1		Electric coil: Relay stuck			
Filter	Alarm	Standard	FltSupAlarm		1x0041	x.xx	B135	x.xx	0	1		Filter alarm for supply filter (pressure drop above set limit)			
Filter	Alarm	Standard	FltExtAlarm		1x0042	x.xx	B136	x.xx	0	1		Filter alarm for extract filter (pressure drop above set limit)			
Heat exchanger	Status	Special	CExcDeIcing		1x0043	x.xx	B1297	6.51	0	1		Reduction of cross-flow exchanger due to de-icing; deicing started			
Heating coil 2, Electric	Status	Standard	ElBattPowerRed		1x0045	x.xx	B1298	6.51	0	1		Electric coil 2 - Output reduction active due to low flow			
Filter	Alarm	Standard	FltSup2Alarm		1x0046	4.18	B1253	4.18	0	1		Filter Alarm for Sup2-Filter (pressure above Limit)			
Filter	Alarm	Standard	FltExt2Alarm		1x0049	4.18	B1254	4.18	0	1		Filter Alarm for Ext2-Filter (pressure above Limit)			
Temp. Supply	Alarm	Standard	SupTempSensErr		1x0050	x.xx	B137	x.xx	0	1		Supply temperature sensor - sensor fault			
Temp. Extract	Alarm	Standard	ExtTempSensErr		1x0051	x.xx	B138	x.xx	0	1		Extract temperature sensor - sensor fault			
Temp. Out door	Alarm	Standard	OutDoorSensErr		1x0052	x.xx	B139	x.xx	0	1		Outdoor temperature sensor - sensor fault			
Temp. Room	Alarm	Standard	RoomSensErr		1x0053	x.xx	B140	x.xx	0	1		Room temperature sensor - sensor fault			
Temp. Exhaust	Alarm	Standard	ExhaustSensErr		1x0054	x.xx	B141	x.xx	0	1		Exhaust temperature sensor - sensor fault			
Heating coil 1, Water	Alarm	Standard	HW1SensErr		1x0055	x.xx	B142	x.xx	0	1		Heating coil temperature sensor - sensor fault			
Heat exchanger	Alarm	Standard	BattEXC_SensEr		1x0056	x.xx	B143	x.xx	0	1		Heat recovery coil temperature sensor - sensor fault			
Heating coil 1, Water	Alarm	Standard	HW1FrosAir		1x0057	x.xx	B144	x.xx	0	1		Heating coil frost alarm			

Cooling coil	Alarm	Standard	Cool_SumAlarm	1x0060	x.xx	BI45	x.xx	0	1	Cooling shared alarm
Cooling coil	Alarm	Standard	Cool_D11_Alarm	1x0061	x.xx	BI46	x.xx	0	1	Cooling digital alarm 1 input
Cooling coil	Alarm	Standard	Cool_D12_Alarm	1x0062	x.xx	BI47	x.xx	0	1	Cooling digital alarm 2 input
Cooling coil	Alarm	Standard	Cool_D13_Alarm	1x0063	x.xx	BI48	x.xx	0	1	Cooling digital alarm 3 input
Cooling coil	Alarm	Standard	Cool_D14_Alarm	1x0064	x.xx	BI49	x.xx	0	1	Cooling digital alarm 4 input
Fan, Supply drive	Status	Standard	SupMotorON	1x0070	x.xx	BI50	x.xx	0	1	Supply motor ON/OFF
Fan, Supply drive	Alarm	Standard	SupMotorAlarm	1x0071	4.18	BI51	4.18	0	1	Supply Motor Alarm
Fan, Supply drive	Alarm	Standard	FCsupMtrAlrVlo	1x0072	x.xx	BI52	x.xx	0	1	Supply motor low voltage alarm (only with OJ-FC)
Fan, Supply drive	Alarm	Standard	FCsupMtrAlrVhi	1x0073	x.xx	BI53	x.xx	0	1	Supply motor high voltage alarm(only with OJ-FC)
Fan, Supply drive	Alarm	Standard	FCsupMtrAlrIhi	1x0074	x.xx	BI54	x.xx	0	1	Supply motor high current alarm (only with OJ-FC), motor protection
Fan, Supply drive	Alarm	Standard	FCsupMtrAlrTtmp	1x0075	x.xx	BI55	x.xx	0	1	Supply motor temperature alarm (only with OJ-FC)
Fan, Supply drive	Alarm	Standard	FCsupMtrAlrPhs	1x0076	x.xx	BI56	x.xx	0	1	Supply motor phase fault alarm (only with OJ-FC)
Fan, Supply drive	Alarm	Standard	FCAlrSupOldRip	1x0077	x.xx	BI299	6.51	0	1	Supply motor ripple voltage alarm (only with OJ-FC)
Fan, Supply drive	Alarm	Standard	FCsupMtrIhiLim	1x0078	x.xx	BI58	x.xx	0	1	Supply motor high current limit: short-circuit protection (only with OJ-FC)
Fan, Supply drive	Alarm	Standard	FCsupMtrAlrRip	1x0079	4.18	BI57	4.18	0	1	Supply Motor V Ripple Alarm
Fan, Extract drive	Status	Standard	ExtMotorON	1x0080	x.xx	BI59	x.xx	0	1	Extract motor ON/OFF
Fan, Extract drive	Alarm	Standard	FCextMtrAlrVlo	1x0082	x.xx	BI61	x.xx	0	1	Extract motor low voltage alarm
Fan, Extract drive	Alarm	Standard	FCextMtrAlrVhi	1x0083	x.xx	BI62	x.xx	0	1	Extract motor high voltage alarm
Fan, Extract drive	Alarm	Standard	FCextMtrAlrIhi	1x0084	x.xx	BI63	x.xx	0	1	Extract motor high current alarm
Fan, Extract drive	Alarm	Standard	FCextMtrAlrTtmp	1x0085	x.xx	BI64	x.xx	0	1	Extract motor temperature alarm (only with OJ-FC)
Fan, Extract drive	Alarm	Standard	FCextMtrAlrPhs	1x0086	x.xx	BI65	x.xx	0	1	Extract motor phase fault alarm
Fan, Extract drive	Alarm	Standard	FCAlrExtOldRip	1x0087	x.xx	BI300	6.51	0	1	Extract motor ripple voltage alarm
Fan, Extract drive	Alarm	Standard	FCextMtrIhiLim	1x0088	x.xx	BI67	x.xx	0	1	Extract motor high current limit
Fan, Extract drive	Alarm	Standard	FCextMtrAlrRip	1x0089	4.18	BI66	4.18	0	1	Extract Motor V Ripple Alarm
Heat exchanger drive	Status	Standard	EXC_ON	1x0090	x.xx	BI68	x.xx	0	1	Rotary heat exchanger – motor control ON/OFF(only with OJ-RHX2M)
Heat exchanger drive	Status	Standard	EXC_Reset	1x0091	x.xx	BI69	x.xx	0	1	Rotary heat exchanger – reset signal (only with OJ-RHX2M)
Heat exchanger drive	Status	Standard	EXC_Direction	1x0092	x.xx	BI70	x.xx	0	1	Rotary heat exchanger – rotation direction (only with OJ-RHX2M)
Heat exchanger drive	Alarm	Standard	EXC_RotAlarm	1x0093	x.xx	BI71	x.xx	0	1	Rotary heat exchanger – rotation alarm (only with OJ-RHX2M)
Heat exchanger drive	Alarm	Standard	EXC_VolAlarm	1x0094	x.xx	BI72	x.xx	0	1	Rotary heat exchanger – low voltage alarm (only with OJ-RHX2M)
Heat exchanger drive	Alarm	Standard	EXC_VhiAlarm	1x0095	x.xx	BI73	x.xx	0	1	Rotary heat exchanger – high voltage alarm(only with OJ-RHX2M)
Heat exchanger drive	Alarm	Standard	EXC_IhiAlarm	1x0096	x.xx	BI74	x.xx	0	1	Rotary heat exchanger – high current alarm (only with OJ-RHX2M)
Heat exchanger drive	Alarm	Standard	EXC_TempAlarm	1x0097	x.xx	BI75	x.xx	0	1	Rotary heat exchanger – temperature alarm (only with OJ-RHX2M)
Heat exchanger drive	Status	Standard	EXC_RotSignal	1x0098	x.xx	BI76	x.xx	0	1	Rotary heat exchanger – rotation signal (only with OJ-RHX2M)
Heat exchanger drive	Alarm	Standard	EXC_Overload	1x0099	x.xx	BI77	x.xx	0	1	Rotary heat exchanger – torque overload (only with OJ-RHX2M)
Preheater coil, electric	Status	Standard	PH_PowReduce	1x0100	x.xx	BI93	x.xx	0	1	Pre-heating coil - Output reduction, low air volume
Preheater coil, water	Status	Standard	PHFrostRegAct	1x0101	x.xx	BI89	x.xx	0	1	Pre-heating coil - Relay for active heating/cooling
Preheater coil	Status	Standard	PHHeatRelay	1x0102	x.xx	BI91	x.xx	0	1	Pre-heating coil - Frost protection active
Preheater coil, water	Alarm	Standard	PHFzrCool	1x0103	x.xx	BI901	6.51	0	1	Pre-heating coil - Frost alarm, cooling
Preheater coil, electric	Alarm	Standard	PH_Overheat	1x0104	x.xx	BI92	x.xx	0	1	Pre-heating coil - Overheating fault
Preheater coil, water	Alarm	Standard	PH_HWBSensErr	1x0105	x.xx	BI94	x.xx	0	1	Pre-heating coil - Return sensor - Sensor fault
Preheater coil, water	Alarm	Standard	PHFreezeAlarm	1x0106	x.xx	BI88	x.xx	0	1	Pre-heating coil - Frost alarm
Preheater coil	Status	Standard	PHHeatRelay2	1x0107	x.xx	BI226	x.xx	0	1	Preheater - heat relay 2
Preheater coil	Status	Special	PHHeatRelay3	1x0108	x.xx	BI176	x.xx	0	1	Pre-heating coil - Heat relay 3 (Heat/Cool)
Preheater coil, water	Status	Standard	PHPumpExer	1x0109	4.18	BI90	4.18	0	1	Pre-heater Pump exercise active
Heat pump	Status	Special	HP_CoolingActv	1x0110	x.xx	BI108	x.xx	0	1	Changeover relay heatpump active
Heat pump	Status	Special	HP_De-icingAct	1x0111	x.xx	BI109	x.xx	0	1	Status bit: De-icing of heatpump
Cooling coil	Status	Special	NO_CStopRTStat	1x0112	x.xx	BI107	x.xx	0	1	Cooling stopped by room temperature
Heat exchanger	Alarm	Special	NO_CRcovStat	1x0113	x.xx	BI106	x.xx	0	1	Coolrecovery over damper active (*1* = Open damper)
Heat exchanger	Alarm	Special	AlrNtrEXCali	1x0114	x.xx	BI104	x.xx	0	1	Alarm - pressure transmitter not calibrated (low guard rotor heat exchanger)
Heat exchanger	Alarm	Special	AlrSensREXNC	1x0115	x.xx	BI105	x.xx	0	1	Alarm - pressure transmitter not configured (low guard rotor heat exchanger)
Heat exchanger	Alarm	Special	AlrRexFrozen	1x0116	x.xx	BI110	x.xx	0	1	Alarm - rotor heat exchanger blocked by ice (high pressure over rotor wheel)
Heat exchanger	Alarm	Special	AlrRexDusty	1x0117	x.xx	BI111	x.xx	0	1	Alarm - rotor heat exchanger blocked by dirt (high pressure over rotor wheel)
Heat exchanger	Alarm	Standard	AlrEXCEFTolow	1x0118	4.18	BI95	4.18	0	1	Alarm - Heat recovery efficiency below alarm limit
Damper, Fire	Alarm	Standard	AlrFireDmpNCls	NA	NA	BI308	6.51	0	1	Alarm, Fire damper not closed
Damper, Fire	Alarm	Standard	AlrFireDmpNOpn	NA	NA	BI309	6.51	0	1	Alarm, Fire damper not open
Damper, Fire	Status	Standard	FireDmpTstActv	NA	NA	BI310	6.51	0	1	Fire damper test is ongoing
Fan Supply Backup	Alarm	Standard	SupMtorAlarm	1x0119	6.51	BI295	6.51	0	1	Supply Backup Motor Alarm
Fan Exhaust Backup	Alarm	Standard	ExhMtorAlarm	1x0120	6.51	BI296	6.51	0	1	Exhaust Backup Motor Alarm
Heat pump	Status	Special	HP_TSExAlrErr	1x0121	6.51	BI311	6.51	0	1	Temperature sensor extract air after HeatPump - Sensor fault
Motor Supply Backup	Alarm	Standard	AlrSupBMr	1x0329	6.51	BI292	6.51	0	1	SupBackupMotor Alarm
Motor Exhaust Backup	Alarm	Standard	AlrExhBMr	1x0330	6.51	BI293	6.51	0	1	ExhBackupMotor Alarm
AHU controller	Alarm	Special	AggBIKAlr	1x0331	6.54	BI312	6.54	0	1	Start of AHU is blocked, if mounted and open
Heating Coil #1 or #2	Fire	Special	FireHtCoilAlr	1x0332	6.54	BI313	6.54	0	1	Firethermostat alarm via Digital Input "Electric heating coil, fire thermostat"
Heating Coil Pre-Heater	Fire	Special	FirePrHeatAlr	1x0333	6.54	BI314	6.54	0	1	Firethermostat alarm via Digital Input "El pre-heating coil, fire thermostat"
Heating coil 2, Water	Alarm	Standard	HW2SensErr	1x0150	x.xx	BI86	x.xx	0	1	Heating coil 2 - Return sensor - Sensor fault
Heating coil 2, Water	Alarm	Standard	HW2FrostAlr	1x0151	x.xx	BI87	x.xx	0	1	Heating coil 2 - Frost alarm
Heating coil 2, Water	Status	Standard	HW2FrosReq	1x0152	x.xx	BI84	x.xx	0	1	Heating coil 2 - Frost control active
Heating coil 2, Water	Status	Standard	HW2PumpExer	1x0153	x.xx	BI85	x.xx	0	1	Heating coil 2 - Circulation pump, pump exercising active
Heater coil 2	Status	Standard	Heat_RE2	1x0154	x.xx	BI278	4.22	0	1	Heating relay 2 (ExtMod-Reserve)
Heating coil 2, Electric	Status	Special	Heat_RE21	1x0155	x.xx	BI212	x.xx	0	1	Heating relay 21 (ExtMod-Reserve)
Heating coil 2, Electric	Status	Special	Heat_RE22	1x0156	x.xx	BI213	x.xx	0	1	Heating relay 22 (ExtMod-Reserve)
Heating coil 2, Electric	Status	Special	Heat_RE23	1x0157	x.xx	BI214	x.xx	0	1	Heating relay 23 (ExtMod-Reserve)
Heating coil 2, Electric	Status	Special	Heat_RE24	1x0159	x.xx	BI215	x.xx	0	1	Heating relay 24 (ExtMod-Reserve)
Heating coil 2, Electric	Status	Special	Heat_RE25	1x0160	x.xx	BI216	x.xx	0	1	Heating relay 25 (ExtMod-Reserve)
Temp. sensor	Alarm	Special	AddOnTSens1Err	1x0161	x.xx	BI79	x.xx	0	1	Add on sensor 1 - Sensor fault
Temp. sensor	Alarm	Special	AddOnTSens2Err	1x0162	x.xx	BI80	x.xx	0	1	Add on sensor 2 - Sensor fault
Temp. sensor	Alarm	Special	AddOnTSens3Err	1x0163	x.xx	BI81	x.xx	0	1	Add on sensor 3 - Sensor fault
Temp. sensor	Alarm	Special	AddOnTSens4Err	1x0164	x.xx	BI82	x.xx	0	1	Add on sensor 4 - Sensor fault
Heating coil 1, Water	Alarm	Standard	HW_StalutAlr	1x0165	x.xx	BI302	6.51	0	1	Status frost thermostat alarm (digital input)
Heat exchanger	Alarm	Standard	AlrFzrBattEXC	1x0166	x.xx	BI100	x.xx	0	1	Frost alarm fluid-coupled coil (CoilEXC)
Humidifier	Alarm	Standard	HumidAlrTnp	1x0169	x.xx	BI303	6.51	0	1	Humidifier alarm status
Combi coil	Alarm	Standard	CombiTSensErr	1x0170	x.xx	BI279	4.22	0	1	Combi coil - Return sensor - Sensor fault
Combi coil	Alarm	Standard	CombiTSensAlrH	1x0171	x.xx	BI280	4.22	0	1	Combi coil - Frost alarm
Combi coil	Status	Standard	CombiFrostReq	1x0172	x.xx	BI281	4.22	0	1	Combi coil - Frost protection active
Combi coil	Status	Standard	CombiPumpExer	1x0173	x.xx	BI282	4.22	0	1	Combi coil - Circulation pump, pump exercising active
Combi coil	Status	Standard	CombiCoolRel	1x0174	x.xx	BI283	4.22	0	1	Combi coil: Cooling relay active
Combi coil	Status	Standard	CombiHeatRel	1x0175	x.xx	BI284	4.22	0	1	Combi coil: Heating relay active
Heating coil 2	Status	Special	HIZDelayStatus	1x0176	x.xx	BI113	x.xx	0	1	Special customer code: Status timer Heat2
Heating coil 2	Status	Special	HIZRecBIKAct	1x0177	x.xx	BI115	x.xx	0	1	Special customer code: Blocking Heat2 in recirculation mode = Aktivated
Heating coil 2	Status	Special	HIZFlowChgAct	1x0178	x.xx	BI112	x.xx	0	1	Special customer code: Flow changed caused Heat2 is aktivated
Damper, Recirculation	Status	Special	IntRecFlowStat	1x0179	x.xx	BI116	x.xx	0	1	Special customer code: Status low flow during 100% recirculation
Damper, Recirculation	Status	Special	RecCloseDmpAct	1x0180	x.xx	BI117	x.xx	0	1	Special customer code: Recirculation damper is closed
Heating coil 2	Status	Special	HT2DaliLimBkNo	1x0181	x.xx	BI114	x.xx	0	1	Special customer code: Limiting Heat2 is not activated
AHU controller	Status	Special	NO_CStopStat	1x0182	x.xx	BI304	6.51	0	1	Special customer code: Stop recirculation air cooling; Stop activated
Heating coil 1	Status	Special	HW1RfIActiv	1x0183	x.xx	BI118	x.xx	0	1	Max. raise-fall-time is aktivated
Damper, Smoke evac.	Alarm	Special	Alr_FireEvaDmp	1x0184	x.xx	BI277	4.22	0	1	Alarm smoke evacuation damper is activated (*1* = Open damper)
Fan, Supply drive 2	Alarm	Special	EC2supMAlrVlo	1x0185	x.xx	BI120	x.xx	0	1	OJ-EC/DV 2-supply air motor voltage low alarm
Fan, Supply drive 2	Alarm	Special	EC2supMAlrVhi	1x0186	x.xx	BI121	x.xx	0	1	OJ-EC/DV 2-supply air motor voltage high alarm
Fan, Supply drive 2	Alarm	Special	EC2supMAlrIhi	1x0187	x.xx	BI122	x.xx	0	1	OJ-EC/DV 2-supply air motor high current limit alarm
Fan, Supply drive 2	Alarm	Special	EC2supMAlrTtmp	1x0188	x.xx	BI123	x.xx	0	1	OJ-EC/DV 2-supply air motor temperature alarm

Fan, Supply drive 2	Alarm	Special	EC2supMAirPhs	1x0189	x.xx	BI124	x.xx	0	1	OJ-EC-DV 2-supply air motor alarm for phase error
Fan, Supply drive 2	Alarm	Special	EC2supRotBlOk	1x0190	x.xx	BI126	x.xx	0	1	OJ-EC-DV 2-supply air motor alarm for blocked rotor
Fan, Supply drive 2	Alarm	Special	EC2supMtrHLim	1x0191	x.xx	BI119	x.xx	0	1	OJ-EC-DV 2-supply supply air motor high current limit; shortcircuit protection
Fan, Extract drive 2	Alarm	Special	EC2extMAirVlo	1x0192	x.xx	BI128	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor voltage low alarm
Fan, Extract drive 2	Alarm	Special	EC2extMAirVhi	1x0193	x.xx	BI129	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor voltage high alarm
Fan, Extract drive 2	Alarm	Special	EC2extMAirIhi	1x0194	x.xx	BI130	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor high current limit alarm
Fan, Extract drive 2	Alarm	Special	EC2extMAirTtmp	1x0195	x.xx	BI131	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor temperature alarm
Fan, Extract drive 2	Alarm	Special	EC2extMAirPhs	1x0196	x.xx	BI132	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor alarm for phase error
Fan, Extract drive 2	Alarm	Special	EC2extRotBlOk	1x0197	x.xx	BI134	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor alarm for blocked rotor
Fan, Extract drive 2	Alarm	Special	EC2extMtrHLim	1x0198	x.xx	BI127	x.xx	0	1	OJ-EC-DV 2-extract/exhaust motor high current limit; shortcircuit protection
Temp. sensor	Alarm	Standard	AirTTH6202Com	1x0199	x.xx	BI155	x.xx	0	1	TTH-6202 communication error
Fan, Supply drive	Alarm	Standard	ECsupMtrAirVlo	1x0200	x.xx	BI138	x.xx	0	1	OJ-EC-DV-supply air motor voltage low alarm
Fan, Supply drive	Alarm	Standard	ECsupMtrAirVhi	1x0201	x.xx	BI139	x.xx	0	1	OJ-EC-DV-supply air motor voltage high alarm
Fan, Supply drive	Alarm	Standard	ECsupMtrAirIhi	1x0202	x.xx	BI140	x.xx	0	1	OJ-EC-DV-supply air motor high current limit alarm
Fan, Supply drive	Alarm	Standard	ECsupMtrAirTtmp	1x0203	x.xx	BI141	x.xx	0	1	OJ-EC-DV-supply air motor temperature alarm
Fan, Supply drive	Alarm	Standard	ECsupMtrAirPhs	1x0204	x.xx	BI142	x.xx	0	1	OJ-EC-DV-supply air motor alarm for phase error
Fan, Supply drive	Alarm	Standard	ECsupRotBlOked	1x0205	x.xx	BI144	x.xx	0	1	OJ-EC-DV-supply air motor alarm for blocked rotor
Fan, Supply drive	Alarm	Standard	ECsupMtrHLim	1x0206	x.xx	BI137	x.xx	0	1	OJ-EC-DV-supply air motor high current limit; shortcircuit protection
Fan, Extract drive	Alarm	Standard	ECextMtrAirVlo	1x0207	x.xx	BI146	x.xx	0	1	OJ-EC-DV-extract/exhaust motor voltage low alarm
Fan, Extract drive	Alarm	Standard	ECextMtrAirVhi	1x0208	x.xx	BI147	x.xx	0	1	OJ-EC-DV-extract/exhaust motor voltage high alarm
Fan, Extract drive	Alarm	Standard	ECextMtrAirIhi	1x0209	x.xx	BI148	x.xx	0	1	OJ-EC-DV-extract/exhaust motor high current limit alarm
Fan, Extract drive	Alarm	Standard	ECextMtrAirTtmp	1x0210	x.xx	BI149	x.xx	0	1	OJ-EC-DV-extract/exhaust motor temperature alarm
Fan, Extract drive	Alarm	Standard	ECextMtrAirPhs	1x0211	x.xx	BI150	x.xx	0	1	OJ-EC-DV-extract/exhaust motor alarm for phase error
Fan, Extract drive	Alarm	Standard	ECextRotBlOked	1x0212	x.xx	BI152	x.xx	0	1	OJ-EC-DV-extract/exhaust motor alarm for blocked rotor
Fan, Extract drive	Alarm	Standard	ECextMtrHLim	1x0213	x.xx	BI145	x.xx	0	1	OJ-EC-DV-extract/exhaust motor high current limit; shortcircuit protection
IO Extension module	Alarm	Standard	AirExtIO1_Comm	1x0214	x.xx	BI158	x.xx	0	1	Extension IO-Modul no. 1 - communication error
IO Extension module	Alarm	Standard	AirExtIO2_Comm	1x0215	x.xx	BI159	x.xx	0	1	Extension IO-Modul no. 2 - communication error
IO Extension module	Alarm	Standard	AirExtIO3_Comm	1x0216	x.xx	BI160	x.xx	0	1	Extension IO-Modul no. 3 - communication error
IO Extension module	Alarm	Standard	AirExtIO4_Comm	1x0217	x.xx	BI161	x.xx	0	1	Extension IO-Modul no. 4 - communication error
IO Extension module	Alarm	Standard	AirExtIO5_Comm	1x0218	x.xx	BI162	x.xx	0	1	Extension IO-Modul no. 5 - communication error
IO Extension module	Alarm	Standard	AirExtIO6_Comm	1x0219	x.xx	BI163	x.xx	0	1	Extension IO-Modul no. 6 - communication error
IO Extension module	Alarm	Standard	AirExtIO7_Comm	1x0220	x.xx	BI164	x.xx	0	1	Extension IO-Modul no. 7 - communication error
IO Extension module	Alarm	Standard	AirExtIO8_Comm	1x0221	x.xx	BI165	x.xx	0	1	External IO-Modul no. 8 - communication error
Temp. sensor	Alarm	Special	AirAddOnSens1	1x0222	x.xx	BI167	x.xx	0	1	Addon sensor 1 - Sensor error
Temp. sensor	Alarm	Special	AirAddOnSens2	1x0223	x.xx	BI168	x.xx	0	1	Addon sensor 2 - Sensor error
Temp. sensor	Alarm	Special	AirAddOnSens3	1x0224	x.xx	BI169	x.xx	0	1	Addon sensor 3 - Sensor error
Temp. sensor	Alarm	Special	AirAddOnSens4	1x0225	x.xx	BI170	x.xx	0	1	Addon sensor 4 - Sensor error
Cooling, DX	Status	Standard	ROHRIFAActiv	1x0226	x.xx	BI174	x.xx	0	1	Special customer code functionality
Combi coil	Status	Standard	CmbEnCtrlMB	NA	x.xx	BI175	4.18	0	1	0 CombiCoil enable Heat/Cool ctrl via MB
Combi coil	Status	Standard	Cmb2CoolRel	1x0227	x.xx	BI173	x.xx	0	1	Combi coil; Cooling relay no. 2 aktive
Fan, Supply drive	Alarm	Standard	ECsupEEP_Err	1x0228	x.xx	BI178	x.xx	0	1	Supply air fan EEPROM error
Fan, Supply drive 2	Alarm	Special	EC2supEEP_Err	1x0229	x.xx	BI179	x.xx	0	1	Supply air fan 2 EEPROM error
Fan, Extract drive	Alarm	Special	EC2extEEP_Err	1x0230	x.xx	BI180	x.xx	0	1	Exhaust air fan EEPROM error
Fan, Extract drive 2	Alarm	Special	EC2extEEP_Err	1x0231	x.xx	BI181	x.xx	0	1	Exhaust air fan 2 EEPROM error
Temp. sensor	Alarm	Standard	TTH6040ComAir	1x0232	x.xx	BI182	x.xx	0	1	TTH-6040 communication error
Cooling, DX	Alarm	Special	LowOIDXHPAlr	1x0233	x.xx	BI183	x.xx	0	1	Low oil level cooling compressor
AHU controller	Fire	Standard	AirFireManStop	1x0234	x.xx	BI203	x.xx	0	1	Fire main stop
Damper, Smoke evac.	Smoke	Standard	AirSmokeActv	1x0235	x.xx	BI204	x.xx	0	1	Smoke evacuation activated
Temp. Room	Alarm	Standard	BMSRoomTOOR	1x0236	x.xx	BI201	x.xx	0	1	BMS room sensor out of range
Temp. Out door	Alarm	Standard	BMSoutDOOR	1x0237	x.xx	BI202	x.xx	0	1	BMS outdoor temperature out of range
Fan, Smoke evac.	Alarm	Standard	AirSmokEveFan	1x0238	x.xx	BI205	x.xx	0	1	Smoke evacuation fan alarm
Damper, Fresh air	Status	Standard	TTH6040OutDAir	1x0239	6.51	BI294	6.51	0	1	Sensor alarm TTH6040 OutDoor no Com (port A)
Damper, Recirculation	Status	Standard	StatInRel	1x0240	x.xx	BI206	x.xx	0	1	Output for outdoor air/exhaust air active ("1" = Open damper)
Temp. Out door	Status	Standard	StatRecRel	1x0241	x.xx	BI207	x.xx	0	1	Output for supply air damper
Preheater coil, water	Alarm	Standard	StatRecRel	1x0242	x.xx	BI208	x.xx	0	1	Output for recirculation damper aktive ("1" = Open damper)
Cooling coil, 1, Electric	Alarm	Standard	ExOutDSensErr	1x0243	x.xx	BI209	x.xx	0	1	External outdoor temperature sensor - sensor error
Heating coil 1, Electric	Alarm	Standard	PHTempSensErr	1x0244	x.xx	BI210	x.xx	0	1	Temperature sensor pre-heater - sensor error
Combi coil	Alarm	Standard	CW_TSensErr	1x0245	x.xx	BI211	x.xx	0	1	Cooling water supply temperature - sensor error
Heating coil 2, Electric	Status	Standard	Heat_REL2	1x0246	x.xx	BI217	x.xx	0	1	Heating relay26 (ExtMod-Reserve)
Filter	Status	Standard	Comb_PumpRE	1x0247	x.xx	BI218	x.xx	0	1	Pump relay combi coil activated
Filter	Alarm	Standard	EL2_OverHBac	1x0248	x.xx	BI221	x.xx	0	1	Electric coil 2: High temperature alarm signal
Filter	Alarm	Standard	AirBat2Contact	1x0249	x.xx	BI222	x.xx	0	1	Electric coil 2: Relay stuck
Filter	Alarm	Standard	OutFIIRAirOn	1x0250	x.xx	BI223	x.xx	0	1	Alarm - Time is out for filter change supply air filter
Filter	Calibration	Standard	ExtFIIRAirOn	1x0251	x.xx	BI224	x.xx	0	1	Alarm - Time is out for filter change exhaust air filter
Fan	Speed	Standard	FillCalDone	NA	NA	BI227	x.xx	0	1	0 Filter Calibration done (valid filterpress data) DYNAMICMODE ONLY
Fan, Supply drive	Alarm	Standard	FCAirSupPoLim	1x0252	x.xx	BI229	x.xx	0	1	Alarm - Supply air fan, Power limit
Fan, Extract drive	Alarm	Standard	FCAirExtPoLim	1x0253	x.xx	BI230	x.xx	0	1	Alarm - Exhaust air fan, Power limit
Fan, Supply drive	Alarm	Standard	FCAirSupDVRBik	1x0254	x.xx	BI231	x.xx	0	1	Alarm - Supply air fan DV-FC Rotor blocked
Fan, Extract drive	Alarm	Standard	FCAirExtDVRBik	1x0255	x.xx	BI232	x.xx	0	1	Alarm - Exhaust air fan, DV-FC Rotor blocked
Fan, Supply drive	Alarm	Standard	DVAirSupStop	1x0256	x.xx	BI233	x.xx	0	1	Alarm - Supply air fan1, High Current Stop
Fan, Supply drive 2	Alarm	Standard	DV2AirSupStop	1x0257	x.xx	BI235	x.xx	0	1	Alarm - Supply air fan2, High Current Stop
Fan, Extract drive	Alarm	Standard	DVAirExtStop	1x0258	x.xx	BI234	x.xx	0	1	Alarm - Exhaust air fan1, High Current Stop
Fan, Extract drive 2	Alarm	Standard	DV2AirExtStop	1x0259	x.xx	BI236	x.xx	0	1	Alarm - Exhaust air fan2, High Current Stop
Combi coil	Status	Standard	CmbHeatState	1x0260	x.xx	BI237	x.xx	0	1	Status combi coil = Heating
Combi coil	Status	Standard	CmbCoolState	1x0261	x.xx	BI238	x.xx	0	1	Status combi coil = Heating
Preheater coil, electric	Alarm	Standard	Pre_OverHBac	1x0262	x.xx	BI239	x.xx	0	1	Alarm = over heating pre-heater
Preheater coil, electric	Alarm	Standard	AirPhContact	1x0263	x.xx	BI240	x.xx	0	1	Alarm = preheater relay hanging
Fan, Supply drive	Alarm	Standard	ECsupHIOAlr	1x0264	x.xx	BI241	x.xx	0	1	Alarm OJ-EC-DV supply air = High IO current
Fan, Extract drive	Alarm	Standard	ECExtHIOAlr	1x0265	x.xx	BI242	x.xx	0	1	Alarm OJ-EC-DV extract air = High IO current
Fan, Supply drive 2	Alarm	Special	EC2supHIOAlr	1x0266	x.xx	BI243	x.xx	0	1	Alarm OJ-EC-DV2 supply air = High IO current
Fan, Extract drive 2	Alarm	Special	EC2ExtHIOAlr	1x0267	x.xx	BI244	x.xx	0	1	Alarm OJ-EC-DV2 extract air = High IO current
CVM Mini Meter	Alarm	Standard	AirCommCVMMini	1x0268	4.21	BI305	6.51	0	1	Communication CVM Mini Meter
CVM Mini Meter	Alarm	Standard	AirCommCVMCool	1x0269	4.21	BI306	6.51	0	1	Communication CVM Mini Cool Meter
Fan, supply	Alarm	Standard	AirSupFanStop	1x0270	4.18	BI245	4.18	0	1	B-Air SupFan is stopped
HMI display	Alarm	Standard	AirCommHM20	1x0271	4.18	BI307	6.51	0	1	A-Air Comm Error HM20
Damper, Smoke evac.	Alarm	Special	AirSMBPassDmp	1x0272	4.18	BI246	4.18	0	1	Smoke Evac Damper not in position
Damper, Smoke evac.	Alarm	Special	AirSMBPassDmp	1x0273	4.18	BI247	4.18	0	1	Smoke Bypass Damper not in position
Pressure	Alarm	Standard	DPTH_1ComAlr	1x0274	4.18	BI248	4.18	0	1	Communication Alarm DPTH1
Pressure	Alarm	Standard	DPTH_2ComAlr	1x0275	4.18	BI249	4.18	0	1	Communication Alarm DPTH2
Pressure	Alarm	Standard	DPTH_3ComAlr	1x0276	4.18	BI250	4.18	0	1	Communication Alarm DPTH3
Pressure	Alarm	Standard	DPTH_4ComAlr	1x0277	4.18	BI251	4.18	0	1	Communication Alarm DPTH4
Pressure	Alarm	Standard	DPTH_5ComAlr	1x0278	4.18	BI252	4.18	0	1	Communication Alarm DPTH5
Filter	Alarm	Standard	SupFIIR2AirOn	1x0279	4.18	BI255	4.18	0	1	Alarm from Supplyfilter2filtertimer
Filter	Alarm	Standard	ExtFIIR2AirOn	1x0280	4.18	BI256	4.18	0	1	Alarm from Extractfilter2timer
Heating	Alarm	Standard	AirFrostLuft	1x0281	4.18	BI83	4.18	0	1	Alarm frost thermostat alarm (digital input)
Fan, Supply drive 2	Alarm	Special	EC2sup_ErrDir	1x0282	4.18	BI125	4.18	0	1	OJ-EC-DV2-Supply air motor Direction error
Fan, Extract drive 2	Alarm	Special	EC2Ext_ErrDir	1x0283	4.18	BI133	4.18	0	1	OJ-EC-DV2-ExtractMotor Direction error
Fan, Supply drive 2	Alarm	Special	AirEC2SupCom	1x0284	4.18	BI135	4.18	0	1	OJ-EC-DV2 Supply Comm Alarm
Fan, Extract drive 2	Alarm	Special	AirEC2ExtCom	1x0285	4.18	BI136	4.18	0	1	OJ-EC-DV2 Extract Comm Alarm
Fan, Supply drive	Alarm	Standard	ECsup_ErrDir	1x0286	4.18	BI143	4.18	0	1	OJ-EC-DV-SupplyMotor Direction error
Fan, Extract drive	Alarm	Standard	ECExt_ErrDir	1x0287	4.18	BI151	4.18	0	1	OJ-EC-DV-ExtractMotor Direction error

Fan, Supply drive	Alarm	Standard	AirOJ_ECS_Comm	1x0288	4.18	BI153	4.18	0	1	OJ-EC-DV Supply Comm Alarm
Fan, Extract drive	Alarm	Standard	AirOJ_ECE_Comm	1x0289	4.18	BI154	4.18	0	1	OJ-EC-DV Extract Comm Alarm
Damper, Smoke evac.	Alarm	Special	AirBDRes7Com	1x0290	4.18	BI156	4.18	0	1	Communication Alarm Belimo ResNo7 Damper
Damper, Smoke evac.	Alarm	Special	AirBDRes7Pos	1x0291	4.18	BI157	4.18	0	1	Position Alarm Belimo ResNo7 Damper
Temp. sensor	Alarm	Special	AirSupTemp2	1x0292	4.18	BI166	4.18	0	1	SupplSensor 2 alarm
Fan, Supply drive	Alarm	Standard	AirSupMtr	1x0293	4.18	BI171	4.18	0	1	SupMotor Alarm
Fan, Extract drive	Alarm	Standard	AirExtMtr	1x0294	4.18	BI172	4.18	0	1	ExtMotor Alarm
Fan, ATV drive	Alarm	Special	AirAtvSupComm	1x0295	4.18	BI96	4.18	0	1	Alarm Atv Communication alarm Supply
Fan, ATV drive	Alarm	Special	AirAtvExtComm	1x0296	4.18	BI97	4.18	0	1	Alarm Atv Communication alarm Extract
Fan, ATV drive	Alarm	Special	AirAtvSupFC	1x0297	4.18	BI98	4.18	0	1	Alarm Atv FC Supply
Fan, ATV drive	Alarm	Special	AirAtvExtFC	1x0298	4.18	BI99	4.18	0	1	Alarm Atv FC Extract
Preheater coil, electric	Alarm	Special	AirDelceCont	1x0299	4.18	BI101	4.18	0	1	Contact error Delcer El-coil
Preheater coil, electric	Alarm	Special	AirDelceOverh	1x0300	4.18	BI102	4.18	0	1	Delcer overheatingalarm El-coil
Preheater coil, electric	Alarm	Special	AirDelceReduc	1x0301	4.18	BI103	4.18	0	1	Delcer power reduction alarm El-coil
Fan, Extract drive	Alarm	Standard	ExtMotorAlarm	1x0302	4.18	BI60	4.18	0	1	ExtMotor ON/OFF
Zone, PIR	Status	Standard	ZM_PIR	1x0303	4.19	BI257	4.19	0	1	ZoneControl PIR Active
Zone 1	Status	Standard	ZM1_WinFrost	1x0304	4.19	BI258	4.19	0	1	ZoneModule 1 - WindowFrost Value
Zone 1	Status	Standard	ZM1_PIR	1x0305	4.19	BI259	4.19	0	1	ZoneModule 1 - PIR Active
Zone 1	Status	Standard	ZM1_RoomTempErr	1x0306	4.19	BI260	4.19	0	1	ZoneModule 1 - Room Temp Sensor Error
Zone 2	Status	Standard	ZM2_WinFrost	1x0307	4.19	BI261	4.19	0	1	ZoneModule 1 - Supply Temp Sensor Error
Zone 2	Status	Standard	ZM2_PIR	1x0308	4.19	BI262	4.19	0	1	ZoneModule 2 - WindowFrost Value
Zone 2	Status	Standard	ZM2_RoomTempErr	1x0309	4.19	BI263	4.19	0	1	ZoneModule 2 - PIR Active
Zone 2	Status	Standard	ZM2_SupTempErr	1x0310	4.19	BI264	4.19	0	1	ZoneModule 2 - Room Temp Sensor Error
Zone 2	Status	Standard	ZM2_SupTempErr	1x0311	4.19	BI265	4.19	0	1	ZoneModule 2 - Supply Temp Sensor Error
Zone 3	Status	Standard	ZM3_WinFrost	1x0312	4.19	BI266	4.19	0	1	ZoneModule 3 - WindowFrost Value
Zone 3	Status	Standard	ZM3_PIR	1x0313	4.19	BI267	4.19	0	1	ZoneModule 3 - PIR Active
Zone 3	Status	Standard	ZM3_RoomTempErr	1x0314	4.19	BI268	4.19	0	1	ZoneModule 3 - Room Temp Sensor Error
Zone 3	Status	Standard	ZM3_SupTempErr	1x0315	4.19	BI269	4.19	0	1	ZoneModule 3 - Supply Temp Sensor Error
Zone 4	Status	Standard	ZM4_WinFrost	1x0316	4.19	BI270	4.19	0	1	ZoneModule 4 - WindowFrost Value
Zone 4	Status	Standard	ZM4_PIR	1x0317	4.19	BI271	4.19	0	1	ZoneModule 4 - PIR Active
Zone 4	Status	Standard	ZM4_RoomTempErr	1x0318	4.19	BI272	4.19	0	1	ZoneModule 4 - Room Temp Sensor Error
Zone 4	Status	Standard	ZM4_SupTempErr	1x0319	4.19	BI273	4.19	0	1	ZoneModule 4 - Supply Temp Sensor Error
Cooling coil	Status	Standard	Cool_RE2	1x0320	4.22	BI274	4.21	0	1	Cooling Relay 2
Cooling coil	Status	Standard	Cool_RE3	1x0321	4.22	BI275	4.21	0	1	Cooling Relay 3
Cooling coil	Status	Standard	Cool_RE4	1x0322	4.22	BI276	4.21	0	1	Cooling Relay 4
Fan Wall, Supply	Alarm	Standard	SupFanWallAir	1x0323	6.30	BI285	6.30	0	1	Supply Fan wall Alarm (B)
Fan Wall, Exhaust	Alarm	Standard	ExtFanWallAir	1x0324	6.30	BI287	6.30	0	1	Extract Fan wall Alarm (B)
Damper, Extract air	Status	Standard	ExtDamperSig	1x0325	6.30	BI288	6.30	0	1	The extract digital damper output signal ("1" = Open damper)
Damper, Exhaust	Status	Standard	ExhDamperSig	1x0326	6.30	BI289	6.30	0	1	The exhaust digital damper output signal ("1" = Open damper)
Damper, Backup Exhaust	Status	Standard	ExhBDamperSig	1x0327	6.30	BI290	6.30	0	1	The exhaust backup digital damper output signal ("1" = Open damper)
Damper, Backup Supply	Status	Standard	SupBDamperSig	1x0328	6.30	BI291	6.30	0	1	The supply backup digital damper output signal ("1" = Open damper)
Fan, supply	Status	Standard	AirComSupFan	1x0500	x.xx	BI185	x.xx	0	1	Common Alarm - supply air fan
Fan, supply	Alarm	Standard	AirComSupFDu	1x0501	x.xx	BI187	x.xx	0	1	Common Alarm - suppr pressure/flow
Fan	Alarm	Standard	AirComExtFan	1x0502	x.xx	BI186	x.xx	0	1	Common Alarm - extract fan
Fan	Alarm	Standard	AirComExtFDu	1x0503	x.xx	BI188	x.xx	0	1	Common Alarm - extract pressure/flow
Heating coil, Water	Alarm	Standard	AirComHW Pump	1x0504	x.xx	BI184	x.xx	0	1	Common Alarm - circulation pump
Heat exchanger	Alarm	Standard	AirComEXC	1x0505	x.xx	BI189	x.xx	0	1	Common Alarm - heat exchanger
Heating coil, Water	Alarm	Standard	AirComFreeze	1x0506	x.xx	BI190	x.xx	0	1	Common Alarm - frost
Heating coil, Electric	Alarm	Standard	AirComElHeat	1x0507	x.xx	BI191	x.xx	0	1	Common Alarm - electric heating coil
AHU controller	Alarm	Standard	AirComTemp	1x0508	x.xx	BI192	x.xx	0	1	Common Alarm - temperature high/low
Filter	Alarm	Standard	AirComSFilter	1x0509	x.xx	BI193	x.xx	0	1	Common Alarm - supply filter
Filter	Alarm	Standard	AirComEFilter	1x0510	x.xx	BI194	x.xx	0	1	Common Alarm - extract filter
Temp. sensor	Alarm	Standard	AirComTmSens	1x0511	x.xx	BI195	x.xx	0	1	Common Alarm - temperature sensor
Cooling coil	Alarm	Standard	AirComCool	1x0512	x.xx	BI196	x.xx	0	1	Common Alarm - cooling
Damper, Direct Modbus	Alarm	Standard	AirComBDamp	1x0513	x.xx	BI197	x.xx	0	1	Common Alarm Belimo damper ("1" = Open damper)
AHU controller	Alarm	Standard	AirComIntern	1x0514	x.xx	BI198	x.xx	0	1	Common Alarm - Internal Modbus error
AHU controller	Status	Standard	BMS_InpStat	1x0515	4.18	BI199	4.18	0	1	Activate BMS control
AHU controller	Status	Standard	ExternLowState	1x0522	x.xx	BI200	x.xx	0	1	Input external low speed
AHU controller	Status	Standard	StartInpState	1x0523	x.xx	BI177	x.xx	0	1	Status external start input
1. Info	1. Info	1. Info	1. Info	Input register (R)	Analog input (R)	1. Info	1. Info	1. Info	1. Info	1. Info
AHU controller	Control	Standard	DriftMode	3x0001	x.xx	A10	x.xx	0	500	Actual operating mode 000-099: Unit stopped 100-199: Unit in low speed mode 200-299: Unit in high speed mode 300-399: Unit in spec. control mode 410-44: Unit in medium speed mode
Pressure	Current value	Standard	SupDuctPa	3x0003	x.xx	A11	x.xx	0	5000	Actual supply duct pressure [Pa]
Pressure	Set point	Standard	SupDuctPaRgSet	3x0004	x.xx	A12	x.xx	0	2000	Setpoint for supply duct pressure controller [Pa]
Pressure	Current value	Standard	ExtDuctPa	3x0005	x.xx	A13	x.xx	0	5000	Actual extract duct pressure [Pa]
Pressure	Set point	Standard	ExtDuctPaRgSet	3x0006	x.xx	A14	x.xx	0	2000	Setpoint for extract duct pressure controller [Pa]
Fan	Current value	Standard	SupFlow	3x0007	x.xx	A15	x.xx	0	30000	Actual supply flow [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Fan	Set point	Standard	SupFlowRegSet	3x0008	x.xx	A16	x.xx	0	30000	Setpoint for supply flow controller [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Fan	Current value	Standard	ExtFlow	3x0009	x.xx	A17	x.xx	0	30000	Actual extract flow [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Fan	Set point	Standard	ExtFlowRegSet	3x0010	x.xx	A18	x.xx	0	30000	Setpoint for extract flow controller [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
CO2 sensor	Current value	Standard	CO2_ppmMeas	3x0011	x.xx	A19	x.xx	0	10000	CO2 concentration recorded by CO2 sensor [ppm]
Fan	Current value	Standard	MtrFanSupVin	3x0012	x.xx	A10	x.xx	0	10000	0-10 V DC signal to supply motor
Fan	Current value	Standard	MtrFanExtVin	3x0013	x.xx	A11	x.xx	0	10000	0-10 V DC signal to extract motor
Fan optimizer	Current value	Standard	FAN_SupPrCMeas	3x0014	x.xx	A12	x.xx	0	10000	Voltage on fan optimizer input: supply signal [1/100%]
Fan optimizer	Current value	Standard	FAN_ExtPrCMeas	3x0015	x.xx	A13	x.xx	0	10000	Voltage on fan optimizer input: extract signal [1/100%]
Fan	Set point	Standard	SupFC_MaxFlow	3x0016	x.xx	A14	x.xx	100	30000	10000 Supply FC max. flow [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Fan	Set point	Standard	ExtFC_MaxFlow	3x0017	x.xx	A15	x.xx	100	30000	10000 Extract FC max. flow [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Temp. Supply	Current value	Standard	SupTemp	3x0020	x.xx	A16	x.xx	-4000	10000	Actual supply temperature [1/100°C]
Temp. Supply	Set point	Standard	SupTempRegSet	3x0021	x.xx	A17	x.xx	0	4000	Setpoint for supply temperature controller [1/100°C]
Temp. Extract	Current value	Standard	ExtTemp	3x0022	x.xx	A18	x.xx	-4000	10000	Actual extract temperature [1/100°C]
Temp. Extract	Set point	Standard	ExtTempRegSet	3x0023	x.xx	A19	x.xx	10	4000	Setpoint for extract temperature controller [1/100°C]
Temp. out door	Current value	Standard	OutDoorTemp	3x0024	x.xx	A120	x.xx	-6000	10000	Actual outdoor temperature [1/100°C] OBS! Only valid when no external outdoor sensor configured - alternative use A123 (3x0024)
Temp. room	Current value	Standard	RoomTemp	3x0025	x.xx	A121	x.xx	-4000	10000	Actual room temperature [1/100°C]
Temp. Exhaust	Current value	Standard	ExhaustTemp	3x0026	x.xx	A122	x.xx	-4000	10000	Actual exhaust temperature [1/100°C]
AHU controller	Current value	Standard	TempRegMeas	3x0027	x.xx	A123	x.xx	-4000	10000	Temp. recorded by actual temperature controller [1/100°C]
AHU controller	Set point	Standard	TempRegVal	3x0028	x.xx	A124	x.xx	0	4000	Control value for actual temperature controller [1/100°C]
Temp. after heat recovery	Current value	Standard	BattEXC_Temp	3x0029	x.xx	A125	x.xx	-4000	10000	Water coil temperature downstream from heat exchanger [1/100°C]
Heating coil 1, Water	Current value	Standard	HW1BattTemp	3x0030	x.xx	A126	x.xx	-4000	10000	Actual heating coil temperature [1/100°C]
Filter	Current value	Standard	SupFltPaAvr	3x0031	x.xx	A127	x.xx	0	5000	Supply filter pressure [Pa]
Filter	Current value	Standard	ExtFltPaAvr	3x0032	x.xx	A128	x.xx	0	5000	Extract filter pressure [Pa]
Filter	Average value	Standard	FltSupFlowAvr	3x0033	x.xx	A126	6.41	0	2000	Average filter supply flow - for internal use only in connection to dynamic filter surveillance [Pa]
Fan	Set point	Standard	SupMotorSet	3x0034	x.xx	A129	x.xx	0	10000	supply motor signal setpoint [1/100%]
Filter	Average value	Standard	FltExtFlowAvr	3x0035	x.xx	A1267	6.41	0	2000	Average filter exhaust flow - for internal use only in connection to dynamic filter surveillance [Pa]
Fan	Set point	Standard	ExtMotorSet	3x0036	x.xx	A130	x.xx	0	10000	Extract motor signal setpoint [%]
Filter	Average value	Standard	FltSupPaAvr	3x0037	x.xx	A1268	6.41	0	3000	Average supfilter-pressure [Pa/30]
Filter	Average value	Standard	FltExtPaAvr	3x0038	x.xx	A1269	6.41	0	3000	Average extfilter-pressure [Pa/30]

Filter	Set point	Standard	FltSupAlrPa	Pa	3x0039	xxx	A131	xxx	0	100	supply filter monitor max. alarm limit [Pa] ONLY IN DYNAMIC MODE ("0" IS STATIC MODE)
Filter	Set point	Standard	EfficiencyTemp	Pa	3x0040	5.07	A1232	5.07	0	100	Current EfficiencyTemp [1/100C]
Temp. heat pump	Current value	Special	HP_OutdCoilTmp	°C	3x0041	xxx	A1270	6.41	-6000	10000	Actual outdoor temperature near outdoor heat pump parts [1/100°C]
Heat exchanger	Current value	Standard	EXCActualEff	%	3x0042	xxx	A1108	xxx	0	10000	Heat exchanger efficiency [1/100%]
Fan, ATV drive	Alarm	Special	AtvSupFCType		3x0043	xxx	A1106	xxx	0	30000	Supply ATV frequency converter - Actual FC type
Fan, ATV drive	Alarm	Special	AtvExtFCType		3x0044	xxx	A1107	xxx	0	30000	Exhaust ATV frequency converter - Actual FC type
Filter	Set point	Standard	FltSup2AlrPa	Pa	3x0045	4.18	A1271	6.41	0	100	Filter pressure for alarm-limit at actual flow [Pa] DYNAMICMODE ONLY (zero in staticmode)
Filter	Set point	Standard	FltExt2AlrPa	Pa	3x0046	4.18	A1272	6.41	0	100	Filter pressure for alarm-limit at actual flow [Pa] DYNAMICMODE ONLY (zero in staticmode)
Filter	Average value	Standard	ExtFlt2PaAvr	Pa	3x0047	4.18	A1130	4.18	0	5000	Extract 2 FlowPressure (Avr-Meas) [Pa] Extract filter monitor max. alarm limit [Pa] ONLY IN DYNAMIC MODE ("0" IS STATIC MODE)
Filter	Average value	Standard	FltExtAlrPa	Pa	3x0048	5.07	A132	5.07	0	1000	Supply 2 FilterPressure (Avr-Meas) [Pa]
AHU controller	Set point	Standard	SubFlt2PaAvr	Pa	3x0049	4.18	A1131	4.18	0	5000	Temp. compensated flow setpoint percentage [1/100%]
AHU controller	Summer/Winter comp.	Standard	FlwTmpCmpOut	%	3x0050	xxx	A133	xxx	0	10000	Summer/winter temp. compensation of actual setpoint offset [1/100°C]
AHU controller	Summer Night Cooling	Standard	SWTC_ActSetOfs	C	3x0051	xxx	A134	xxx	-1000	1000	Summer/Night Time with Heat Demand [sec]
Heat exchanger	Set point	Standard	SN_HeatTime	Sec	3x0052	xxx	A1273	6.41	0	30000	Heat exchange controller heating power [1/100%]
Heating	Set point	Standard	HeatEXCPower	%	3x0053	xxx	A155	xxx	0	10000	Actual heating power [1/100%]
Heating	Set point	Standard	HeatPower	%	3x0054	xxx	A136	xxx	0	10000	Cooling controller power [1/100%]
Cooling coil	Set point	Standard	CoolPower	%	3x0055	xxx	A137	xxx	0	10000	Actual cooling power [1/100%]
Cooling coil	Set point	Standard	CoolActPower	%	3x0056	xxx	A138	xxx	0	10000	Cooling forced flow power [1/100%]
Cooling coil	Set point	Standard	CoolFlwForcePw	%	3x0057	xxx	A139	xxx	0	10000	Cooling alarm 1 transducer signal [1/100%]
Cooling, DX	Current value	Standard	CoolVin1Alarm	%	3x0058	xxx	A140	xxx	0	10000	Cooling alarm 2 transducer signal [1/100%]
Cooling, DX	Current value	Standard	CoolVin2Alarm	%	3x0059	xxx	A141	xxx	0	10000	Cooling alarm 3 transducer signal [1/100%]
Cooling, DX	Current value	Standard	CoolVin3Alarm	%	3x0060	xxx	A142	xxx	0	10000	Cooling alarm 4 transducer signal [1/100%]
Cooling, DX	Current value	Standard	CoolVin4Alarm	%	3x0061	xxx	A143	xxx	0	10000	Actual low pressure sensor 1 [1/100 bar]
Cooling, DX	Current value	Standard	C_HIPress1Bar	Bar	3x0063	xxx	A145	xxx	0	10000	Actual high pressure sensor 1 [1/100 bar]
Cooling, DX	Current value	Standard	C_LoPress2Bar	Bar	3x0064	xxx	A146	xxx	0	10000	Actual high pressure sensor 2 [1/100 bar]
Cooling, DX	Current value	Standard	C_HIPress2Bar	Bar	3x0065	xxx	A147	xxx	0	10000	Heating 2 - Regulator power [1/100%]
Heater coil 2	Set point	Standard	Heat2Power	%	3x0066	xxx	A1103	xxx	0	10000	Supply motor type (only with OJ-FC)
Fan, Supply drive	Current value	Standard	FCsupMtrType		3x0070	xxx	A148	xxx	0	256	Supply motor software version [1/100] (only with OJ-FC)
Fan, Supply drive	SW version	Standard	FCsupMtrFC_SW		3x0071	xxx	A149	xxx	0	1000	Supply motor IO card software version [1/100] (only with OJ-FC)
Fan, Supply drive	Current value	Standard	FCsupMtrIO_SW		3x0072	xxx	A150	xxx	0	1000	Supply motor output percentage [1/100%] (only with OJ-FC)
Fan, Supply drive	Current value	Standard	FCsupMtrProcOut	%	3x0073	xxx	A151	xxx	0	10000	Supply motor frequency output [1/100 Hz] (only with OJ-FC)
Fan, Supply drive	Current value	Standard	FCsupMtrHzOut	Hz	3x0074	xxx	A152	xxx	0	10000	Supply motor actual current output [mA] (only with OJ-FC)
Fan, Supply drive	Current value	Standard	FCsupMtrIout	mA	3x0075	xxx	A153	xxx	0	30000	Supply motor actual power output [Watt] (only with OJ-FC)
Fan, Supply drive	Current value	Standard	FCsupMtrPowOut	W	3x0076	xxx	A154	xxx	0	6000	Supply motor setpoint [%]
Fan, Supply drive	Set point	Standard	FCsupMtrPrCSet	%	3x0077	xxx	A155	xxx	0	10000	Specific fan power (SFP), supply [W /m³/s = J/m³] (only with OJ-FC)
Fan, Supply drive	Current value	Standard	SupSFP	J/m	3x0078	xxx	A156	xxx	0	10000	Supply SFP EC-2 [W/m³/s same as J/m³]
Fan, Supply drive	Current value	Standard	SupSFP1	J/m	3x0079	5.07	A1251	5.07	0	10000	Extract motor type (only with OJ-FC)
Fan, Extract drive	Current value	Standard	FCextMtrType		3x0080	xxx	A157	xxx	0	256	Extract motor software version [1/100] (only with OJ-FC)
Fan, Extract drive	SW version	Standard	FCextMtrFC_SW		3x0081	xxx	A158	xxx	0	1000	Extract motor IO card software version [1/100] (only with OJ-FC)
Fan, Extract drive	Current value	Standard	FCextMtrIO_SW		3x0082	xxx	A159	xxx	0	1000	Extract motor output percentage [1/100%] (only with OJ-FC)
Fan, Extract drive	Current value	Standard	FCextMtrProcOut	%	3x0083	xxx	A160	xxx	0	10000	Extract motor frequency output [1/100 Hz] (only with OJ-FC)
Fan, Extract drive	Current value	Standard	FCextMtrHzOut	Hz	3x0084	xxx	A161	xxx	0	10000	Extract motor actual current output [mA] (only with OJ-FC)
Fan, Extract drive	Current value	Standard	FCextMtrIout	mA	3x0085	xxx	A162	xxx	0	30000	Extract motor actual power output [Watt] (only with OJ-FC)
Fan, Extract drive	Current value	Standard	FCextMtrPowOut	W	3x0086	xxx	A163	xxx	0	6000	Extract motor output setpoint [1/100%]
Fan, Extract drive	Set point	Standard	FCextMtrPrCSet	%	3x0087	xxx	A164	xxx	0	10000	Specific fan power (SFP), extract [W /m³/s = J/m³] (only with OJ-FC)
Fan, Extract drive	Current value	Standard	ExtSFP	J/m	3x0088	xxx	A165	xxx	0	10000	Rotary heat exchanger – motor type (only with OJ RHX2M)
Heat exchanger drive	Current value	Standard	ExtSFP1	J/m	3x0089	5.07	A1252	5.07	0	10000	Rotary heat exchanger – software version [1/100] (only with OJ RHX2M)
Heat exchanger drive	SW version	Standard	EXC_Type		3x0090	xxx	A166	xxx	0	9	Rotary heat exchanger – percentage [1/100%]
Heat exchanger drive	Current value	Standard	EXC_Software	%	3x0091	xxx	A167	xxx	0	10000	Rotary heat exchanger – speed output [1/100 rpm]
Heat exchanger drive	Current value	Standard	EXC_RpmOut	rpm	3x0093	xxx	A169	xxx	0	20000	Rotary heat exchanger – actual output [mA] (only with OJ RHX2M)
Heat exchanger drive	Current value	Standard	EXC_Iout	mA	3x0094	xxx	A170	xxx	0	10000	Rotary heat exchanger – output power [W] (only with OJ RHX2M)
Heat exchanger drive	Current value	Standard	EXC_Power	W	3x0095	xxx	A171	xxx	0	100	Rotary heat exchanger – percentage setpoint [1/100%] (only with OJ RHX2M)
Heat exchanger drive	Current value	Standard	EXC_DrftDays	Day	3x0096	xxx	A172	xxx	0	32000	Combined SFP [W/m³/s same as J/m³]
Heat exchanger drive	Set point	Standard	EXC_PrcSet	%	3x0097	xxx	A173	xxx	0	10000	Extension module 2 software version [1/100]
Heat exchanger drive	Set point	Standard	FullSFPHigh	J/m	3x0098	5.07	A1253	5.07	0	10000	Actual temperature of pre-heating coil [1/100°C]
Heat exchanger drive	Set point	Standard	FullSFPLow	J/m	3x0099	5.07	A1254	5.07	0	10000	Actual output of pre-heating coil [1/100%]
IO Extension module	SW version	Standard	EXTM1_SW_Ver		3x0100	xxx	A174	xxx	0	10000	Actual day of the week (0=Mon..6=Sun)
IO Extension module	SW version	Standard	EXTM2_SW_Ver		3x0101	xxx	A175	xxx	0	10000	Extended operation, remaining number of days
Preheater coil	Current value	Standard	PHWMTemp	°C	3x0102	xxx	A105	xxx	-4000	10000	Extended operation, remaining number of minutes
Preheater coil	Set point	Standard	PH_HeatPower	%	3x0103	xxx	A1104	xxx	0	10000	Actual temperature extract air after HeatPump [1/100°C]
AHU controller	Time	Standard	TimeSw-WeekDay		3x0110	xxx	A176	xxx	0	6	Actual day of the week (0=Mon..6=Sun)
AHU controller	Status	Standard	ExtDrfDaysLeft		3x0111	xxx	A177	xxx	0	6	Extended operation, remaining number of days
AHU controller	Status	Standard	ExtDrfMinLeft	Min	3x0112	xxx	A178	xxx	0	1439	Extended operation, remaining number of minutes
Heat pump	Status	Special	HP_ExtAirTemp	°C	3x0113	6.51	A1338	6.51	-5000	10000	Actual pressure at the heat pump outdoor coil.
Heat pump	Current value	Special	HP_CoilPaMeas	Pa	3x0115	xxx	A1110	xxx	0	5000	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released00		3x0120	xxx	A179	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released01		3x0121	xxx	A180	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released02		3x0122	xxx	A181	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released03		3x0123	xxx	A182	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released04		3x0124	xxx	A183	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released05		3x0125	xxx	A184	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released06		3x0126	xxx	A185	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released07		3x0127	xxx	A186	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released08		3x0128	xxx	A187	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released09		3x0129	xxx	A188	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released10		3x0130	xxx	A189	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released11		3x0131	xxx	A190	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released12		3x0132	xxx	A191	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released13		3x0133	xxx	A192	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released14		3x0134	xxx	A193	xxx	0	100	Stack for active alarms (0 indicates end of stack)
AHU controller	Alarm	Standard	Air_Released15		3x0135	xxx	A194	xxx	0	100	Stack for active alarms (0 indicates end of stack)
Humidity	Current value	Standard	Humid_ActRHOut		3x0138	6.10	A1263	6.10	0	100	Actual % rel. Humidity Outdoor
Humidity	Current value	Standard	Humid_ActRHExh		3x0139	6.10	A1264	6.10	0	100	Actual % rel. Humidity Exhaust
AHU controller	SW version	Standard	MasterSW_Ver		3x0140	xxx	A195	xxx	0	30000	Master software version [1/100]
HMI display	SW version	Standard	DisplaySW_Ver		3x0141	xxx	A196	xxx	0	30000	Display software version [1/100]
Damper, Fire	Alarm	Standard	AirFireDmpNClc		3x0142	xxx	NA	NA	0	1	Alarm, Fire damper not closed
Damper, Fire	Alarm	Standard	AirFireDmpNOpn		3x0143	xxx	NA	NA	0	1	Alarm, Fire damper not open
Damper, Fire	Status	Standard	FireDmpTstActv		3x0144	xxx	NA	NA	0	1	Fire damper test is ongoing
Cooling, DX	Status	Standard	DX_OnTimerRE1	Sec	3x0145	xxx	A1274	6.41	0	600	Timer for DX-Cool RE-1 ON-Period [sec] (ExtMod-Reserve)
Cooling, DX	Status	Standard	DX_OnTimerRE2	Sec	3x0146	xxx	A1275	6.41	0	600	Timer for DX-Cool RE-2 ON-Period [sec] (ExtMod-Reserve)
Cooling, DX	Status	Standard	DX_OnTimerRE3	Sec	3x0147	xxx	A1276	6.41	0	600	Timer for DX-Cool RE-3 ON-Period [sec] (ExtMod-Reserve)
Cooling, DX	Status	Standard	DX_OnTimerRE4	Sec	3x0148	xxx	A1277	6.41	0	600	Timer for DX-Cool RE-4 ON-Period [sec] (ExtMod-Reserve)
Cooling, DX	Status	Standard	DX_RestartCnt1		3x0149	xxx	A1278	6.41	0	60	Counter for DX-Cool RE-1 starts per hour (ExtMod-Reserve)
Heating coil 2, Water	Current value	Standard	HW2BattTemp	°C	3x0150	xxx	A1279	6.41	-4000	10000	Heating 2 - Hydronic coil return temperature [1/100°C]
Cooling, DX	Status	Standard	DX_RestartCnt3		3x0151	xxx	A1280	6.41	0	60	Counter for DX-Cool RE-3 starts per hour (ExtMod-Reserve)

Cooling, DX	Status	Standard	DX_RestartCnt4	Sec	3x0152	x.xx	A1281	6.41	0	60	Counter for DX-Cool RE-4 starts per hour (ExtMod-Reserve)
Cooling, DX	Status	Standard	DX_RestartTIm1	Sec	3x0153	x.xx	A1282	6.41	0	3600	Timer 1 for min. restart period [sec]
Cooling, DX	Status	Standard	DX_RestartTIm2	Sec	3x0154	x.xx	A1283	6.41	0	3600	Timer 2 for min. restart period [sec]
Cooling, DX	Status	Standard	DX_RestartTIm3	Sec	3x0155	x.xx	A1284	6.41	0	100	Timer 3 for min. restart period [sec]
Cooling, DX	Status	Standard	DX_RestartTIm4	Sec	3x0156	x.xx	A1285	6.41	0	3600	Timer 4 for min. restart period [sec]
Filter	Current value	Standard	FltSupPrCStat	%	3x0157	x.xx	A1286	6.41	0	10000	Filter actual alarmstatus for sup-filter [1/100%]
Filter	Current value	Standard	FltExtPrCStat	%	3x0158	x.xx	A1287	6.41	0	10000	Filter actual alarmstatus for ext-filter [1/100%]
Filter	Current value	Standard	FltSupNewPa	Pa	3x0159	x.xx	A1288	6.41	0	100	Filter pressure for new-filter actual flow [Pa]
Filter	Current value	Standard	FltExtNewPa	Pa	3x0160	x.xx	A1289	6.41	0	100	Filter pressure for ext-filter actual flow [Pa]
Temp. sensor	Current value	Special	AddOnTSensor1	°C	3x0161	x.xx	A197	x.xx	-4000	10000	Add on sensor 1 [1/100°C]
Temp. sensor	Current value	Special	AddOnTSensor2	°C	3x0162	x.xx	A198	x.xx	-4000	10000	Add on sensor 2 [1/100°C]
Temp. sensor	Current value	Special	AddOnTSensor3	°C	3x0163	x.xx	A199	x.xx	-4000	10000	Add on sensor 3 [1/100°C]
Temp. sensor	Current value	Special	AddOnTSensor4	°C	3x0164	x.xx	A1100	x.xx	-4000	10000	Add on sensor 4 [1/100°C]
Fan	Current value	Standard	MtrFanSupVIn	%	NA	x.xx	A1101	x.xx	0	10000	0-10 V DC signal to supply motor
Fan	Current value	Standard	MtrFanExVIn	%	NA	x.xx	A1102	x.xx	0	10000	0-10 V DC signal to extract motor
Cooling, DX	Set point	Special	ROHCondPower	%	3x0165	x.xx	A1290	6.41	0	10000	Only special customer code: Step-up valve - Output [1/100%]
Cooling, DX	Set point	Special	ROHCondOutVDC	V	3x0166	x.xx	A1291	6.41	0	10000	Only special customer code: Step-up valve - Voltage [1/1000 V]
Cooling, DX	Set point	Special	ROHShuntPower	%	3x0167	x.xx	A1292	6.41	0	10000	Only special customer code: Condenser coil - Output [1/100%]
Cooling, DX	Set point	Special	ROHShuntOutVDC	V	3x0168	x.xx	A1293	6.41	0	10000	Only special customer code: Condenser coil - Voltage [1/1000 V]
Humidifier	Set point	Standard	Humid_OutVDC	V	3x0169	x.xx	A1294	6.41	0	10000	Output to Steam Humidifier [1/1000 V]
Humidity	Current value	Standard	Humid_ActRHSup	%	3x0170	x.xx	A1128	x.xx	0	10000	Actual % rel. Humidity Supply duct [1/100%rh]
Humidity	Current value	Standard	Humid_ActRHExt	%	3x0171	x.xx	A1129	x.xx	0	10000	Actual % rel. Humidity Extract duct [1/100%rh]
Heating coil 12	Set point	Special	HW12_VDCOut	mV	NA	x.xx	A1107	x.xx	0	10000	Only special customer code: Heat coil 1, step2 output (1,2) VDC out
Damper, Recirculation	Status	Special	RecAirFlowAct	%	3x0172	x.xx	A1111	x.xx	2	2	Only special customer code: Actual status change flow rears. - 0=No change; 1=Low to high; 2=High to low
Damper, Recirculation	Status	Special	RecCloTimer	Sec	3x0173	x.xx	A1112	x.xx	0	7200	Only special customer code: Actual status timer for lukket recirkulering [Sec]
Heating coil 2	Status	Special	H1ZDelayTimer	Sec	3x0174	x.xx	A1295	6.41	0	7200	Only special customer code: Timer delayed Heat2 [Sec]
Heat exchanger	Current value	Special	REXCPressAvg	%	3x0175	x.xx	A1296	6.41	0	2000	Only special customer code: Actual press. drop over rotary exch. in exhaust air [Pa]
Combi coil	Set point	Standard	CombVDC_Out	V	3x0176	x.xx	A1113	x.xx	0	10000	Combi coil VDC-Signal [1/1000 V]
Combi coil	Set point	Standard	CombHeatPow	%	3x0177	x.xx	A1115	x.xx	0	10000	Combi coil %Signal heating [1/100 %]
Combi coil	Set point	Standard	CombCoolPow	%	NA	x.xx	A1116	x.xx	0	10000	Combi coil %Signal Cooling [1/100 %]
Combi coil	Current value	Special	HeatPmpHeatPow	%	3x0178	x.xx	A1297	6.41	0	10000	Heat pump efficiency in heat demand. Else CoolPower [1/100 %]
Fan, Supply drive 2	Current value	Special	EC2supMType	%	3x0179	x.xx	A1298	6.41	0	256	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor Type
Fan, Supply drive 2	SW version	Special	EC2supMEC_SW	%	3x0180	x.xx	A1299	6.41	0	1000	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor Software Ver [1/100]
Fan, Supply drive 2	SW version	Special	EC2supBoot_SW	%	3x0181	x.xx	A1300	6.41	0	1000	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor Boot Software Ver [1/100]
Fan, Supply drive 2	Current value	Special	EC2supPrCOut	%	3x0182	x.xx	A1301	6.41	0	10000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor percent output [1/100%]
Fan, Supply drive 2	Current value	Special	EC2supMRPMOut	RPM	3x0183	x.xx	A1302	6.41	0	10000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor actual RPM [RPM]
Fan, Supply drive 2	Current value	Special	EC2supMlOut	mA	3x0184	x.xx	A1303	6.41	0	30000	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor actual current output [mA]
Fan, Supply drive 2	Current value	Special	EC2supMPowOut	W	3x0185	x.xx	A1304	6.41	0	7000	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor actual power output [Watt]
Fan, Supply drive 2	Current value	Special	EC2supDriftMin	Min	3x0186	x.xx	A1305	6.41	0	1440	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor actual running time [minutes]
Fan, Supply drive 2	Current value	Special	EC2supDriftDay	Day	3x0187	x.xx	A1306	6.41	0	30000	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor actual running time [days]
Fan, Supply drive 2	Set point	Special	EC2supMPrCSet	%	3x0188	x.xx	A1307	6.41	0	10000	Only special customer code: OJ-ECI-DV 2-supply/Supply air motor setpoint [1/100%]
Fan, Extract drive 2	Current value	Special	EC2extMType	%	3x0189	x.xx	A1308	6.41	0	256	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor Type
Fan, Extract drive 2	SW version	Special	EC2extMEC_SW	%	3x0190	x.xx	A1309	6.41	0	1000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor Software Ver [1/100]
Fan, Extract drive 2	SW version	Special	EC2extBoot_SW	%	3x0191	x.xx	A1310	6.41	0	1000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor Boot Software Ver [1/100]
Fan, Extract drive 2	Current value	Special	EC2extMPrCOut	%	3x0192	x.xx	A1311	6.41	0	10000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor percent output [1/100%]
Fan, Extract drive 2	Current value	Special	EC2extMRPMOut	RPM	3x0193	x.xx	A1312	6.41	0	10000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor actual RPM [RPM]
Fan, Extract drive 2	Current value	Special	EC2extMlOut	mA	3x0194	x.xx	A1313	6.41	0	30000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor actual current output [mA]
Fan, Extract drive 2	Current value	Special	EC2extMPowOut	W	3x0195	x.xx	A1314	6.41	0	7000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor actual power output [Watt]
Fan, Extract drive 2	Current value	Special	EC2extDriftMin	Min	3x0196	x.xx	A1315	6.41	0	1440	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor actual running time [minutes]
Fan, Extract drive 2	Current value	Special	EC2extDriftDay	Day	3x0197	x.xx	A1316	6.41	0	30000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor actual running time [days]
Fan, Extract drive 2	Set point	Special	EC2extMPrCSet	%	3x0198	x.xx	A1317	6.41	0	10000	Only special customer code: OJ-ECI-DV 2-Extract/Exhaust air motor setpoint [1/100%]
Fan, Supply drive	Current value	Standard	ECcsupMtrType	%	3x0200	x.xx	A1318	6.41	0	256	OJ-ECI-DV-supply/Supply air motor Type
Fan, Supply drive	SW version	Standard	ECcsupMtrFC_SW	%	3x0201	x.xx	A1319	6.41	0	1000	OJ-ECI-DV-supply/Supply air motor Software Ver [1/100]
Fan, Supply drive	Current value	Standard	ECcsupBoot_SW	%	3x0202	x.xx	A1320	6.41	0	1000	OJ-ECI-DV-supply/Supply air motor Boot Software Ver [1/100]
Fan, Supply drive	Current value	Standard	ECcsupMPrCOut	%	3x0203	x.xx	A1321	6.41	0	10000	OJ-ECI-DV-supply/Supply air motor percent udgang [1/100%]
Fan, Supply drive	Current value	Standard	ECcsupMtrRPMOut	RPM	3x0204	x.xx	A1322	6.41	0	10000	OJ-ECI-DV-supply/Supply air motor actual RPM [RPM]
Fan, Supply drive	Current value	Standard	ECcsupMtrOut	mA	3x0205	x.xx	A1323	6.41	0	30000	OJ-ECI-DV-supply/Supply air motor actual current output [1/100mA]
Fan, Supply drive	Current value	Standard	ECcsupMtrPowOut	W	3x0206	x.xx	NA	NA	0	7000	OJ-ECI-DV-supply/Supply air motor actual power output [Watt]
Fan, Supply drive	Current value	Standard	ECcsupDriftMin	Min	3x0207	x.xx	A1324	6.41	0	1440	OJ-ECI-DV-supply/Supply air motor actual running time [minutes]
Fan, Supply drive	Current value	Standard	ECcsupDriftDay	Day	3x0208	x.xx	A1325	6.41	0	30000	OJ-ECI-DV-supply/Supply air motor actual running time [days]
Fan, Supply drive	Set point	Standard	ECcsupMPrCSet	%	3x0209	x.xx	A1326	6.41	0	10000	OJ-ECI-DV-supply/Supply air motor setpoint [1/100%]
Fan, Extract drive	SW version	Standard	ECextBoot_SW	%	3x0210	x.xx	A1327	6.41	0	1000	OJ-ECI-DV-Extract/Exhaust air motor Boot Software Ver [1/100]
Fan, Extract drive	Current value	Standard	ECextMPrCOut	%	3x0211	x.xx	A1328	6.41	0	10000	OJ-ECI-DV-Extract/Exhaust air motor percent udgang [1/100%]
Fan, Extract drive	Current value	Standard	ECextMtrRPMOut	RPM	3x0212	x.xx	A1329	6.41	0	10000	OJ-ECI-DV-Extract/Exhaust air motor actual RPM [RPM]
Fan, Extract drive	Current value	Standard	ECextMlOut	mA	3x0213	x.xx	A1330	6.41	0	30000	OJ-ECI-DV-Extract/Exhaust air motor actual current output [1/100mA]
Fan, Extract drive	Current value	Standard	ECextMtrPowOut	W	3x0214	x.xx	NA	NA	0	7000	OJ-ECI-DV-Extract/Exhaust air motor actual power output [Watt]
Fan, Extract drive	Current value	Standard	ECextDriftMin	Min	3x0215	x.xx	A1331	6.41	0	1440	OJ-ECI-DV-Extract/Exhaust air motor actual running time [minutes]
Fan, Extract drive	Current value	Standard	ECextDriftDay	Day	3x0216	x.xx	A1332	6.41	0	30000	OJ-ECI-DV-Extract/Exhaust air motor actual running time [days]
Fan, Extract drive	Current value	Standard	ECextMPrCSet	%	3x0217	x.xx	A1333	6.41	0	10000	OJ-ECI-DV-Extract/Exhaust air motor setpoint [1/100%]
Fan, Extract drive	Current value	Standard	ECextMtrType	%	3x0218	x.xx	A1334	6.41	0	256	OJ-ECI-DV-Extract/Exhaust air motor Type
Fan, Extract drive	SW version	Standard	ECextMtrFC_SW	%	3x0219	x.xx	A1335	6.41	0	1000	OJ-ECI-DV-Extract/Exhaust air motor Software Ver [1/100]
Temp. Supply 2	Current value	Standard	SupplyTemp2	°C	3x0220	x.xx	A1234	5.07	-4000	10000	Only special customer code: Actual supply supply temperature2 [1/100°C]
Temp. out door	Current value	Standard	ExtOutDTemp	°C	3x0221	x.xx	A1118	x.xx	-6000	10000	External outdoor temperature sensor [1/100°C]
Preheater coil	Current value	Standard	PHeatTempAir	°C	3x0222	x.xx	A1119	x.xx	-4000	10000	Temperature after pre-heating coil [1/100 °C]
Cooling coil	Current value	Standard	CW_supplyTemp	°C	3x0223	x.xx	A1120	x.xx	-4000	10000	Cold water supply temperature for cooling coil [1/100 °C]
Damper, Recirculation	Status	Standard	RecFreshAirDis	%	3x0224	x.xx	A1121	x.xx	0	10000	Damper position intake/outdoor damper [1/100%]
Damper, Recirculation	Status	Standard	RecDampPrCDis	%	3x0225	x.xx	A1122	x.xx	0	10000	Damper position recirculation [1/100 %]
Cooling coil	Set point	Standard	CoolVDC_Out2	V	3x0226	x.xx	A1123	x.xx	0	10000	Output voltage cooling valve2 (only combi coil) [1/1000 V]
Fan, ATV drive	Current value	Special	AtvExtPower	kW	3x0227	x.xx	A1116	x.xx	0	30000	ATV extract air actual power [1/100 kW]
Fan, ATV drive	Current value	Special	AtvSupPower	kW	3x0228	x.xx	A1117	x.xx	0	30000	ATV supply air actual power [1/100 kW]
Filter	Status	Standard	OutDoorSenTemp	%	3x0229	5.07	A1233	5.07	0	4000	Current OutDoorTemp [1/100°C]
Filter	Status	Standard	OutFltRestDay	Day	3x0230	x.xx	A1124	x.xx	0	366	Days until timer alarm from the outdoor filter
Filter	Status	Standard	ExtFltRestDay	Day	3x0231	x.xx	A1125	x.xx	0	366	Days until timer alarm from the extract filter
Combi coil	Current value	Standard	CombiBattTemp	°C	NA	x.xx	A1126	x.xx	-4000	10000	combi coil - Actual return temperature [1/100°C]
Humidity	Current value	Standard	RelHumMixed	%	3x0232	x.xx	A1129	x.xx	0	10000	Actual relative humidity in mixed air [1/100%rh]
Filter	Status	Standard	SupFlzRestDay	%	3x0233	4.18	A1336	6.41	0	366	Supply filter 2: Resttime before change filter alarm will be activated
Filter	Status	Standard	ExtFlzRestDay	%	3x0234	4.19	A1337	6.41	0	366	Extract filter 2: Resttime before change filter alarm will be activated
Zone	Status	Standard	ZM_Count	%	3x0235	4.19	A1132	4.19	0	4	Number of Detected ZoneModules
Zone	Status	Standard	ZM_OpMode	%	3x0236	4.19	A1133	4.19	0	7	ZoneControl Operation Mode
Zone 1	Status	Standard	ZM1_Status	%	3x0237	4.19	A1134	4.19	0	2	ZoneModule 1 - Status: 0=No active alarm; 1=A-alarm active; 2=B-alarm active
Zone 1	Status	Standard	ZM1_Sup1Set	%	3x0238	4.19	A1135	4.19	0	0	ZoneModule 1 - VAV Supply 1 Actuator Setpoint [scale depending on the connected actuator]
Zone 1	Status	Standard	ZM1_Sup1Flow	%	3x0239	4.19	A1136	4.19	0	0	ZoneModule 1 - VAV Supply 1 Actuator Flow [scale depending on the connected actuator]
Zone 1	Status	Standard	ZM1_Sup2Set	%	3x0240	4.19	A1137	4.19	0	0	ZoneModule 1 - VAV Supply 2 Actuator Setpoint [scale depending on the connected actuator]
Zone 1	Status	Standard	ZM1_Sup2Flow	%	3x0241	4.19	A1138	4.19	0	0	ZoneModule 1 - VAV Supply 2 Actuator Flow [scale depending on the connected actuator]
Zone 1	Status	Standard	ZM1_ExtSet	%	3x0242	4.19	A1139	4.19	0	0	ZoneModule 1 - VAV Extract Actuator Setpoint [scale depending on the connected actuator]
Zone 1	Status	Standard	ZM1_ExtFlow	%	3x0243	4.19	A1140	4.19	0	0	ZoneModule 1 - VAV Extract Actuator Flow

Zone 1	Status	Standard	ZM1_SetOffset	3x0250	4.19	A1147	4.19	-4000	10000	ZoneModule 1 - Remote Setpoint Offset [1/100°C]
Zone 1	Status	Standard	ZM1_CO2VOC	3x0251	4.19	A1148	4.19	0	5000	ZoneModule 1 - CO2/VOC Value [ppm]
Zone 1	Status	Standard	ZM1_RH	3x0252	4.19	A1149	4.19	0	10000	ZoneModule 1 - RH Value [1/100%rh]
Zone 2	Status	Standard	ZM2_Status	3x0253	4.19	A1150	4.19	0	2	ZoneModule 2 - Status: 0=No active alarm; 1=A-alarm active; 2=B-alarm active
Zone 2	Status	Standard	ZM2_Sup1Set	3x0254	4.19	A1151	4.19	0	0	ZoneModule 2 - VAV Supply 1 Actuator Setpoint [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_Sup1Flow	3x0255	4.19	A1152	4.19	0	0	ZoneModule 2 - VAV Supply 1 Actuator Flow [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_Sup2Set	3x0256	4.19	A1153	4.19	0	0	ZoneModule 2 - VAV Supply 2 Actuator Setpoint [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_Sup2Flow	3x0257	4.19	A1154	4.19	0	0	ZoneModule 2 - VAV Supply 2 Actuator Flow [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_ExtSet	3x0258	4.19	A1155	4.19	0	0	ZoneModule 2 - VAV Extract Actuator Setpoint [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_ExtFlow	3x0259	4.19	A1156	4.19	0	0	ZoneModule 2 - VAV Extract Actuator Flow [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_HeatSet	3x0260	4.19	A1157	4.19	0	0	ZoneModule 2 - VAV Heating Actuator Setpoint [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_HeatFlow	3x0261	4.19	A1158	4.19	0	0	ZoneModule 2 - VAV Heating Actuator Flow [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_CoolSet	3x0262	4.19	A1159	4.19	0	0	ZoneModule 2 - VAV Cooling Actuator Setpoint [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_CoolFlow	3x0263	4.19	A1160	4.19	0	0	ZoneModule 2 - VAV Cooling Actuator Flow [scale depending on the connected actuator]
Zone 2	Status	Standard	ZM2_RoomTemp	3x0264	4.19	A1161	4.19	-4000	10000	ZoneModule 2 - Room Temperature Value [1/100°C]
Zone 2	Status	Standard	ZM2_SupTemp	3x0265	4.19	A1162	4.19	-4000	10000	ZoneModule 2 - Supply Temperature Value [1/100°C]
Zone 2	Status	Standard	ZM2_SetOffset	3x0266	4.19	A1163	4.19	-4000	10000	ZoneModule 2 - Remote Setpoint Offset [1/100°C]
Zone 2	Status	Standard	ZM2_CO2VOC	3x0267	4.19	A1164	4.19	0	5000	ZoneModule 2 - CO2/VOC Value [ppm]
Zone 2	Status	Standard	ZM2_RH	3x0268	4.19	A1165	4.19	0	10000	ZoneModule 2 - RH Value [1/100%rh]
Zone 3	Status	Standard	ZM3_Status	3x0269	4.19	A1166	4.19	0	2	ZoneModule 3 - Status: 0=No active alarm; 1=A-alarm active; 2=B-alarm active
Zone 3	Status	Standard	ZM3_Sup1Set	3x0270	4.19	A1167	4.19	0	0	ZoneModule 3 - VAV Supply 1 Actuator Setpoint [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_Sup1Flow	3x0271	4.19	A1168	4.19	0	0	ZoneModule 3 - VAV Supply 1 Actuator Flow [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_Sup2Set	3x0272	4.19	A1169	4.19	0	0	ZoneModule 3 - VAV Supply 2 Actuator Setpoint [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_Sup2Flow	3x0273	4.19	A1170	4.19	0	0	ZoneModule 3 - VAV Supply 2 Actuator Flow [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_ExtSet	3x0274	4.19	A1171	4.19	0	0	ZoneModule 3 - VAV Extract Actuator Setpoint [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_ExtFlow	3x0275	4.19	A1172	4.19	0	0	ZoneModule 3 - VAV Extract Actuator Flow [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_HeatSet	3x0276	4.19	A1173	4.19	0	0	ZoneModule 3 - VAV Heating Actuator Setpoint [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_HeatFlow	3x0277	4.19	A1174	4.19	0	0	ZoneModule 3 - VAV Heating Actuator Flow [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_CoolSet	3x0278	4.19	A1175	4.19	0	0	ZoneModule 3 - VAV Cooling Actuator Setpoint [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_CoolFlow	3x0279	4.19	A1176	4.19	0	0	ZoneModule 3 - VAV Cooling Actuator Flow [scale depending on the connected actuator]
Zone 3	Status	Standard	ZM3_RoomTemp	3x0280	4.19	A1177	4.19	-4000	10000	ZoneModule 3 - Room Temperature Value [1/100°C]
Zone 3	Status	Standard	ZM3_SupTemp	3x0281	4.19	A1178	4.19	-4000	10000	ZoneModule 3 - Supply Temperature Value [1/100°C]
Zone 3	Status	Standard	ZM3_SetOffset	3x0282	4.19	A1179	4.19	-4000	10000	ZoneModule 3 - Remote Setpoint Offset [1/100°C]
Zone 3	Status	Standard	ZM3_CO2VOC	3x0283	4.19	A1180	4.19	0	5000	ZoneModule 3 - CO2/VOC Value [ppm]
Zone 3	Status	Standard	ZM3_RH	3x0284	4.19	A1181	4.19	0	10000	ZoneModule 3 - RH Value [1/100%rh]
Zone 4	Status	Standard	ZM4_Status	3x0285	4.19	A1182	4.19	0	2	ZoneModule 4 - Status: 0=No active alarm; 1=A-alarm active; 2=B-alarm active
Zone 4	Status	Standard	ZM4_Sup1Set	3x0286	4.19	A1183	4.19	0	0	ZoneModule 4 - VAV Supply 1 Actuator Setpoint [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_Sup1Flow	3x0287	4.19	A1184	4.19	0	0	ZoneModule 4 - VAV Supply 1 Actuator Flow [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_Sup2Set	3x0288	4.19	A1185	4.19	0	0	ZoneModule 4 - VAV Supply 2 Actuator Setpoint [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_Sup2Flow	3x0289	4.19	A1186	4.19	0	0	ZoneModule 4 - VAV Supply 2 Actuator Flow [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_ExtSet	3x0290	4.19	A1187	4.19	0	0	ZoneModule 4 - VAV Extract Actuator Setpoint [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_ExtFlow	3x0291	4.19	A1188	4.19	0	0	ZoneModule 4 - VAV Extract Actuator Flow [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_HeatSet	3x0292	4.19	A1189	4.19	0	0	ZoneModule 4 - VAV Heating Actuator Setpoint [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_HeatFlow	3x0293	4.19	A1190	4.19	0	0	ZoneModule 4 - VAV Heating Actuator Flow [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_CoolSet	3x0294	4.19	A1191	4.19	0	0	ZoneModule 4 - VAV Cooling Actuator Setpoint [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_CoolFlow	3x0295	4.19	A1192	4.19	0	0	ZoneModule 4 - VAV Cooling Actuator Flow [scale depending on the connected actuator]
Zone 4	Status	Standard	ZM4_RoomTemp	3x0296	4.19	A1193	4.19	-4000	10000	ZoneModule 4 - Room Temperature Value [1/100°C]
Zone 4	Status	Standard	ZM4_SupTemp	3x0297	4.19	A1194	4.19	-4000	10000	ZoneModule 4 - Supply Temperature Value [1/100°C]
Zone 4	Status	Standard	ZM4_SetOffset	3x0298	4.19	A1195	4.19	-4000	10000	ZoneModule 4 - Remote Setpoint Offset [1/100°C]
Zone 4	Status	Standard	ZM4_CO2VOC	3x0299	4.19	A1196	4.19	0	5000	ZoneModule 4 - CO2/VOC Value [ppm]
Zone 4	Status	Standard	ZM4_RH	3x0300	4.19	A1197	4.19	0	10000	ZoneModule 4 - RH Value [1/100%rh]
CVM Meter	Status	Standard	CVMVoltageL1	3x0301	4.21	A1198	4.21	0	5200	CVM Phase L1 to neutral (N) voltage [V]
CVM Meter	Status	Standard	CVMCurrentL1	3x0302	4.21	A1199	4.21	0	6000	CVM Current L1 value [A]
CVM Meter	Status	Standard	CVMActivePowerL1	3x0303	4.21	A1200	4.21	0	65535	CVM Active power [kW]
CVM Meter	Status	Standard	CVMVoltageL2	3x0304	4.21	A1201	4.21	0	5200	CVM Phase L2 to neutral (N) voltage [V]
CVM Meter	Status	Standard	CVMCurrentL2	3x0305	4.21	A1202	4.21	0	6000	CVM Current L2 value [A]
CVM Meter	Status	Standard	CVMActivePowerL2	3x0306	4.21	A1203	4.21	0	65535	CVM Active power [kW]
CVM Meter	Status	Standard	CVMVoltageL3	3x0307	4.21	A1204	4.21	0	5200	CVM Phase L3 to neutral (N) voltage [V]
CVM Meter	Status	Standard	CVMCurrentL3	3x0308	4.21	A1205	4.21	0	6000	CVM Current L3 value [A]
CVM Meter	Status	Standard	CVMActivePowerL3	3x0309	4.21	A1206	4.21	0	65535	CVM Active power [kW]
CVM Meter	Status	Standard	CVMActivePowerIII	3x0310	4.21	A1207	4.21	0	65535	CVM Active power three phases [W] (Low Byte)
CVM Meter	Status	Standard	CVMFrequency	3x0311	4.21	A1208	4.21	0	600	CVM Frequency value [Hz]
CVM Meter	Status	Standard	CVMVoltageL1L2	3x0312	4.21	A1209	4.21	0	5200	CVM Phase-phase Voltage L1 to L2 [V]
CVM Meter	Status	Standard	CVMVoltageL2L3	3x0313	4.21	A1210	4.21	0	5200	CVM Phase-phase Voltage L2 to L3 [V]
CVM Meter	Status	Standard	CVMVoltageL3L1	3x0314	4.21	A1211	4.21	0	5200	CVM Phase-phase Voltage L3 to L1 [V]
CVM Meter	Status	Standard	CVMActiveEnergyIII	3x0315	4.26	A1230	5.07	0	65535	CVM Active energy three phases [kWh]
CVM Meter	Status	Standard	CVMCurrentL1H	3x0316	5.07	A1235	5.07	0	65535	CVM Current value [mA] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMActivePowerL1H	3x0317	5.07	A1236	5.07	0	65535	CVM Active power [W] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMCurrentL2H	3x0318	5.07	A1237	5.07	0	65535	CVM Current value [mA] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMActivePowerL2H	3x0319	5.07	A1238	5.07	0	65535	CVM Active power [W] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMCurrentL3H	3x0320	5.07	A1239	5.07	0	65535	CVM Current value [mA] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMActivePowerL3H	3x0321	5.07	A1240	5.07	0	65535	CVM Active power [W] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMActivePowerIIH	3x0322	5.07	A1241	5.07	0	65535	CVM Active power three phases [W] (High Byte) - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMActiveEnergyIIH	3x0323	5.07	A1242	5.07	0	65535	CVM Active energy three phases [Wh] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CVMVoltageL1	3x0330	4.21	A1212	4.21	0	5200	CCVM Cool Phase L1 to neutral (N) voltage [V]
CVM Meter	Status	Standard	CVMCurrentL1	3x0331	4.21	A1213	4.21	0	6000	CCVM Cool Current L1 value [A]
CVM Meter	Status	Standard	CVMActivePowerL1	3x0332	4.21	A1214	4.21	0	65535	CCVM Cool Active power [kW]
CVM Meter	Status	Standard	CCVMVoltageL2	3x0333	4.21	A1215	4.21	0	5200	CCVM Cool Phase L2 to neutral (N) voltage [V]
CVM Meter	Status	Standard	CCVMCurrentL2	3x0334	4.21	A1216	4.21	0	6000	CCVM Cool Current L2 value [A]
CVM Meter	Status	Standard	CCVMActivePowerL2	3x0335	4.21	A1217	4.21	0	65535	CCVM Cool Active power [kW]
CVM Meter	Status	Standard	CCVMVoltageL3	3x0336	4.21	A1218	4.21	0	5200	CCVM Cool Phase L3 to neutral (N) voltage [V]
CVM Meter	Status	Standard	CCVMCurrentL3	3x0337	4.21	A1219	4.21	0	6000	CCVM Cool Current L3 value [A]
CVM Meter	Status	Standard	CCVMActivePowerL3	3x0338	4.21	A1220	4.21	0	65535	CCVM Cool Active power [kW]
CVM Meter	Status	Standard	CCVMActivePowerIII	3x0339	4.21	A1221	4.21	0	65535	CCVM Cool Active power three phases [W] (Low Byte)
CVM Meter	Status	Standard	CCVMFrequency	3x0340	4.21	A1222	4.21	0	600	CCVM Cool Frequency value [Hz]
CVM Meter	Status	Standard	CCVMVoltageL1L2	3x0341	4.21	A1223	4.21	0	5200	CCVM Cool Phase-phase Voltage L1 to L2 [V]
CVM Meter	Status	Standard	CCVMVoltageL2L3	3x0342	4.21	A1224	4.21	0	5200	CCVM Cool Phase-phase Voltage L2 to L3 [V]
CVM Meter	Status	Standard	CCVMVoltageL3L1	3x0343	4.21	A1225	4.21	0	5200	CCVM Cool Phase-phase Voltage L3 to L1 [V]
CVM Meter	Status	Standard	CCVMActiveEnergyIII	3x0344	4.26	A1231	4.26	0	65535	CCVM Cool Active energy three phases [kWh]
CVM Meter	Status	Standard	CCVMCurrentL1H	3x0345	5.07	A1243	5.07	0	65535	CCVM Current value [mA] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActivePowerL1H	3x0346	5.07	A1244	5.07	0	65535	CCVM Active power [W] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMCurrentL2H	3x0347	5.07	A1245	5.07	0	65535	CCVM Current value [mA] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActivePowerL2H	3x0348	5.07	A1246	5.07	0	65535	CCVM Active power [W] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMCurrentL3H	3x0349	5.07	A1247	5.07	0	65535	CCVM Current value [mA] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActivePowerL3H	3x0350	5.07	A1248	5.07	0	65535	CCVM Active power [W] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActivePowerIIH	3x0351	5.07	A1249	5.07	0	65535	CCVM Active power three phases [W] (High Byte) - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActiveEnergyIIH	3x0352	5.07	A1250	5.07	0	65535	CCVM Active energy three phases [Wh] - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActiveEnergyIII	3x0353	5.21	A1255	5.21	0	65535	CVM E3 Mini Active energy three phases [kWh] High byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActiveEnergyI	3x0354	5.21	A1256	5.21	0	65535	CVM E3 Mini Active energy three phases [kWh] Low byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActiveEnergyII	3x0355	5.21	A1257	5.21	0	65535	CVM E3 Mini Active energy three phases [kWh] High byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActiveEnergyIII	3x0356	5.21	A1258	5.21	0	65535	CVM E3 Mini Active energy three phases [kWh] Low byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVMActiveEnergyI	3x0357	5.21	A1259	5.21	0	65535	CVM E3 Mini Active energy three phases [kWh] High byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer

CVM Meter	Status	Standard	CCVME3CKActEn3	3x0358	5.21	AI260	5.21	0	65535	CCVM E3 Mini Active energy three phases [kWh] Low byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVME3CWActEn3H	3x0359	5.21	AI261	5.21	0	65535	CCVM E3 Mini Active energy three phases [Wh] High byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
CVM Meter	Status	Standard	CCVME3CWActEn3	3x0360	5.21	AI262	5.21	0	65535	CCVM E3 Mini Active energy three phases [Wh] Low byte - Note!: Values are calculated as (High byte) x 65536 + (Low byte) - High and low bytes = Integer
Heating coil, Electric	Status	Special	EIBattActPow	3x0104	6.41	AI226	4.21	0	30000	Actual power (kW) electrical battery 1
Heating coil, Electric	Status	Special	EIBatt2ActPow	3x0105	6.41	AI227	4.21	0	30000	Actual power (kW) electrical battery 2
Fan, supply	Status	Special	ECsupMtrPowOut	NA	NA	AI228	4.21	0	30000	Actual power (kW) Supply fan
Fan, extract	Status	Special	ECextMtrPowOut	NA	NA	AI229	4.21	0	30000	Actual power (kW) Extract fan

1. Info	1. Info	1. Info	1. Info	1. Info	Holding register (R/W)	Analog value (R/W)	1. Info	1. Info	1. Info	1. Info
AHU controller	Set point	ManDriftMode	4x0001	x.xx	AV0	x.xx	0	7	0=Auto 1=Manual stop 2=Manual low 3=Manual high 6=Manual medium 7=Calender 0=pressure 1=flow 2=extract slave 3=supply slave 4=external V DC setpoint 5=fan optimizer supply/extract 6=fan optimizer with extract slave 7=Green Zone 8=Green Zone slave 9=Constant speed	
AHU controller	Set point	MtrReglMode	4x0002	x.xx	AV1	x.xx	0	12	0 4 5 6 7 8 9	
Pressure	Set point	SupDuctPaLoSet	Pa 4x0003	x.xx	AV2	x.xx	0	2000	50 Setpoint for duct pressure, low supply [Pa]	
Pressure	Set point	SupDuctPaHiSet	Pa 4x0004	x.xx	AV3	x.xx	0	2000	200 Setpoint for duct pressure, high supply [Pa]	
Fan	Set point	SupDuctMinFlow	l/s 4x0005	x.xx	AV4	x.xx	0	30000	1500 Min. supply duct flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	SupDuctMaxFlow	l/s 4x0006	x.xx	AV5	x.xx	0	30000	10000 Max. supply duct flow P322	
Pressure	Set point	ExtDuctPaLoSet	Pa 4x0007	x.xx	AV6	x.xx	0	2000	50 Setpoint for low duct pressure, extract [Pa]	
Pressure	Set point	ExtDuctPaHiSet	Pa 4x0008	x.xx	AV7	x.xx	0	2000	200 Setpoint for high duct pressure, extract [Pa]	
Fan	Set point	ExtDuctMinFlow	l/s 4x0009	x.xx	AV8	x.xx	0	30000	1500 Min. extract duct flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	ExtDuctMaxFlow	l/s 4x0010	x.xx	AV9	x.xx	0	30000	10000 Max. extract duct flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	SupLoSpeedSet	l/s 4x0011	x.xx	AV10	x.xx	0	30000	3000 Setpoint for supply flow, low speed [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	SupHiSpeedSet	l/s 4x0012	x.xx	AV11	x.xx	0	30000	7000 Setpoint for supply flow, high speed [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	ExtLoSpeedSet	l/s 4x0014	x.xx	AV12	x.xx	0	30000	3000 Setpoint for extract flow, low speed [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	ExtHiSpeedSet	l/s 4x0015	x.xx	AV13	x.xx	0	30000	7000 Setpoint for extract flow, high speed [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan	Set point	MtrRegOffset	% 4x0017	x.xx	AV14	x.xx	-5000	5000	0 Supply/extract motor offset, slave and CO2 control [1/100%]	
Fan	Set point	MtrRegOffset	% NA	NA	AV15	x.xx	-5000	5000	0 Supply/extract motor offset, slave and CO2 control [1/100%]	
Fan	Set point	MtrRegOffset	% NA	NA	AV16	x.xx	-5000	5000	0 Supply/extract motor offset, slave and CO2 control [1/100%]	
CO2 sensor	Set point	CO2_UserSetLP	ppm 4x0020	x.xx	AV17	x.xx	0	10000	1000 CO2 control: setpoint for low period (high CO2 value) [ppm]	
CO2 sensor	Set point	CO2_UserSetHP	ppm 4x0021	x.xx	AV18	x.xx	0	10000	1000 CO2 control: setpoint for high period (high CO2 value) [ppm]	
CO2 sensor	Set point	CO2_MinFlow	l/s 4x0022	x.xx	AV19	x.xx	0	30000	3000 CO2 control: min. flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
CO2 sensor	Set point	CO2_MaxFlow	l/s 4x0023	x.xx	AV20	x.xx	0	30000	7000 CO2 control: max. flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
CO2 sensor	Set point	CO2_SupFlwOffs	% 4x0024	x.xx	AV21	x.xx	-5000	5000	0 CO2 control: supply flow offset [1/100%]	
CO2 sensor	Alarm	CO2_AirLimit	ppm 4x0025	x.xx	AV22	x.xx	100	10000	2000 CO2 concentration alarm limit setpoint [ppm]	
CO2 sensor	Control	CO2_PB	ppm 4x0026	x.xx	AV23	x.xx	10	10000	500 CO2 control: P-band [ppm]	
CO2 sensor	Control	CO2_I_Time	sec 4x0027	x.xx	AV24	x.xx	10	30000	700 CO2 control: I-time [sec]	
Fan optimizer	Set point	FAN_SupMinFlow	l/s 4x0028	x.xx	AV25	x.xx	0	30000	2000 Fan optimizer supply control: min. flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan optimizer	Set point	FAN_SupMaxFlow	l/s 4x0029	x.xx	AV26	x.xx	0	30000	10000 Fan optimizer extract control: min. flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan optimizer	Set point	FAN_ExtMinFlow	l/s 4x0030	x.xx	AV27	x.xx	0	30000	2000 Fan optimizer supply control: max. flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan optimizer	Set point	FAN_ExtMaxFlow	l/s 4x0031	x.xx	AV28	x.xx	0	30000	10000 Fan optimizer extract control: max. flow [l/s] or [m ³ /h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)	
Fan optimizer	Set point	FAN_ExtFlwOffs	% 4x0032	x.xx	AV29	x.xx	-5000	5000	0 Fan optimizer extract control: flow offset [1/100%]	
Fan	Control	Standard	SupMtr_I_Time	sec 4x0033	x.xx	AV30	x.xx	5	1000	50 Supply motor control: I-time setpoint [sec]
Fan	Control	Standard	ExtMtr_I_Time	sec 4x0034	x.xx	AV31	x.xx	5	1000	50 Extract motor control: I-time setpoint [sec]
Fan	Fire	SupFlowFireSet	% 4x0035	x.xx	AV32	x.xx	0	10000	8000 Supply motor speed setpoint in case of fire alarm [%]	
Fan	Fire	ExtFlowFireSet	% 4x0036	x.xx	AV33	x.xx	0	10000	8000 Extract motor speed setpoint in case of fire alarm [%]	
Fan	Control	HS_AfterRunSet	% 4x0037	x.xx	AV34	x.xx	0	480	0 Run-on time, high speed [min]	
Fan	Set point	FlwTmpCmpSet	% 4x0040	x.xx	AV35	x.xx	0	5000	2500 Reduction of flow / percentage of setpoint [1/100%]	
Fan	Set point	FlwTmpCmpStart	°C 4x0041	x.xx	AV36	x.xx	-1000	1500	500 Reduction of flow / start temp. setpoint [1/100°C]	
Fan	Set point	FlwTmpCmpStop	°C 4x0042	x.xx	AV37	x.xx	-3000	-1000	-2000 Reduction of flow / stop temp. setpoint [1/100°C]	
Cooling, DX	Set point	Special	DXOutTempMin1	°C 4x0043	x.xx	AV211	x.xx	0	4000	1600 Min. outdoor temperature for activating DX relay no. 1
Cooling, DX	Set point	Special	DXOutTempMin2	°C 4x0044	x.xx	AV212	x.xx	0	4000	1600 Min. outdoor temperature for activating DX relay no. 2
Cooling, DX	Set point	Special	DXOutTempMin3	°C 4x0045	x.xx	AV213	x.xx	0	4000	1600 Min. outdoor temperature for activating DX relay no. 3
Cooling, DX	Set point	Special	DXOutTempMin4	°C 4x0046	x.xx	AV214	x.xx	0	4000	1600 Min. outdoor temperature for activating DX relay no. 4
AHU controller	Time	Standard	TimeSw-Year	4x0050	x.xx	AV38	x.xx	2000	2099	Actual year
AHU controller	Time	Standard	TimeSw-Month	4x0051	x.xx	AV39	x.xx	1	12	Actual month
AHU controller	Time	Standard	TimeSw-Date	4x0052	x.xx	AV40	x.xx	1	31	Actual date
AHU controller	Time	Standard	TimeSw-Hour	4x0053	x.xx	AV41	x.xx	0	23	Actual hour
AHU controller	Time	Standard	TimeSw-Minute	4x0054	x.xx	AV42	x.xx	0	59	Actual minutes
AHU controller	Time	Standard	TimeSw-Second	4x0055	x.xx	AV43	x.xx	0	59	Actual seconds
AHU controller	Control	Standard	ExtDrfStartDay	4x0056	x.xx	AV44	x.xx	0	6	0 Extended operation start – day (0=Mon..6=Sun)
AHU controller	Control	Standard	ExtDrfStartMin	4x0057	x.xx	AV45	x.xx	0	1439	0 Extended operation start – time (hours times 60 plus minutes)
AHU controller	Control	Standard	ExtDrfStopDay	4x0058	x.xx	AV46	x.xx	0	6	0 Extended operation stop – day (0=Mon..6=Sun)
AHU controller	Control	Standard	ExtDrfStopMin	4x0059	x.xx	AV47	x.xx	0	1439	0 Extended operation stop – time (hours times 60 plus minutes)
AHU controller	Week Schedule	Standard	TimeSw-DayMode	4x0060	x.xx	AV48	x.xx	0	2	0 Timer program type (0..2)=Mon..Sun, 1=Mon..Fri+weekend, 2=all week
AHU controller	Week Schedule	Standard	TimeSw-Start0	4x0061	x.xx	AV49	x.xx	0	1439	480 Monday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start01	4x0062	x.xx	AV50	x.xx	0	1439	960 Tuesday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start02	4x0063	x.xx	AV51	x.xx	0	1439	360 Wednesday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start03	4x0064	x.xx	AV52	x.xx	0	1439	0 Thursday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start04	4x0065	x.xx	AV53	x.xx	0	1439	480 Friday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start05	4x0066	x.xx	AV54	x.xx	0	1439	960 Saturday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start06	4x0067	x.xx	AV55	x.xx	0	1439	360 Sunday: First period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start07	4x0068	x.xx	AV56	x.xx	0	1439	0 Monday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start08	4x0069	x.xx	AV57	x.xx	0	1439	480 Tuesday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start09	4x0070	x.xx	AV58	x.xx	0	1439	960 Wednesday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start10	4x0071	x.xx	AV59	x.xx	0	1439	360 Thursday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start11	4x0072	x.xx	AV60	x.xx	0	1439	0 Friday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start12	4x0073	x.xx	AV61	x.xx	0	1439	480 Saturday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start13	4x0074	x.xx	AV62	x.xx	0	1439	960 Sunday: Second period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start14	4x0075	x.xx	AV63	x.xx	0	1439	360 Monday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start15	4x0076	x.xx	AV64	x.xx	0	1439	0 Tuesday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start16	4x0077	x.xx	AV65	x.xx	0	1439	480 Wednesday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start17	4x0078	x.xx	AV66	x.xx	0	1439	960 Thursday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start18	4x0079	x.xx	AV67	x.xx	0	1439	360 Friday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start19	4x0080	x.xx	AV68	x.xx	0	1439	0 Saturday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start20	4x0081	x.xx	AV69	x.xx	0	1439	480 Sunday: Third period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start21	4x0082	x.xx	AV70	x.xx	0	1439	960 Monday: Fourth period start time [minutes after midnight]

AHU controller	Week Schedule	Standard	TimeSw-Start22	Min	4x0083	xxx	AV71	xxx	0	1439	360	Tuesday: Fourth period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start23	Min	4x0084	xxx	AV72	xxx	0	1439	0	Wednesday: Fourth period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start24	Min	4x0085	xxx	AV73	xxx	0	1439	480	Thursday: Fourth period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start25	Min	4x0086	xxx	AV74	xxx	0	1439	960	Friday: Fourth period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start26	Min	4x0087	xxx	AV75	xxx	0	1439	360	Saturday: Fourth period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Start27	Min	4x0088	xxx	AV76	xxx	0	1439	0	Sunday: Fourth period start time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop00	Min	4x0089	xxx	AV77	xxx	1	1440	960	Monday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop01	Min	4x0090	xxx	AV78	xxx	1	1440	1440	Tuesday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop02	Min	4x0091	xxx	AV79	xxx	1	1440	480	Wednesday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop03	Min	4x0092	xxx	AV80	xxx	1	1440	360	Thursday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop04	Min	4x0093	xxx	AV81	xxx	1	1440	960	Friday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop05	Min	4x0094	xxx	AV82	xxx	1	1440	1440	Saturday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop06	Min	4x0095	xxx	AV83	xxx	1	1440	480	Sunday: First period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop07	Min	4x0096	xxx	AV84	xxx	1	1440	360	Monday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop08	Min	4x0097	xxx	AV85	xxx	1	1440	960	Tuesday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop09	Min	4x0098	xxx	AV86	xxx	1	1440	1440	Wednesday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop10	Min	4x0099	xxx	AV87	xxx	1	1440	480	Thursday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop11	Min	4x0100	xxx	AV88	xxx	1	1440	360	Friday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop12	Min	4x0101	xxx	AV89	xxx	1	1440	960	Saturday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop13	Min	4x0102	xxx	AV90	xxx	1	1440	1440	Sunday: Second period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop14	Min	4x0103	xxx	AV91	xxx	1	1440	480	Monday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop15	Min	4x0104	xxx	AV92	xxx	1	1440	360	Tuesday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop16	Min	4x0105	xxx	AV93	xxx	1	1440	960	Wednesday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop17	Min	4x0106	xxx	AV94	xxx	1	1440	1440	Thursday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop18	Min	4x0107	xxx	AV95	xxx	1	1440	480	Friday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop19	Min	4x0108	xxx	AV96	xxx	1	1440	360	Saturday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop20	Min	4x0109	xxx	AV97	xxx	1	1440	960	Sunday: Third period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop21	Min	4x0110	xxx	AV98	xxx	1	1440	1440	Monday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop22	Min	4x0111	xxx	AV99	xxx	1	1440	480	Tuesday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop23	Min	4x0112	xxx	AV100	xxx	1	1440	360	Wednesday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop24	Min	4x0113	xxx	AV101	xxx	1	1440	960	Thursday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop25	Min	4x0114	xxx	AV102	xxx	1	1440	1440	Friday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop26	Min	4x0115	xxx	AV103	xxx	1	1440	480	Saturday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Stop27	Min	4x0116	xxx	AV104	xxx	1	1440	360	Sunday: Fourth period stop time [minutes after midnight]
AHU controller	Week Schedule	Standard	TimeSw-Mode00	Min	4x0117	xxx	AV105	xxx	0	6	2	Monday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode01	Min	4x0118	xxx	AV106	xxx	0	6	1	Tuesday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode02	Min	4x0119	xxx	AV107	xxx	0	6	0	Wednesday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode03	Min	4x0120	xxx	AV108	xxx	0	6	0	Thursday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode04	Min	4x0121	xxx	AV109	xxx	0	6	2	Friday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode05	Min	4x0122	xxx	AV110	xxx	0	6	1	Saturday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode06	Min	4x0123	xxx	AV111	xxx	0	6	1	Sunday: First period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode07	Min	4x0124	xxx	AV112	xxx	0	6	0	Monday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode08	Min	4x0125	xxx	AV113	xxx	0	6	2	Tuesday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode09	Min	4x0126	xxx	AV114	xxx	0	6	1	Wednesday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode10	Min	4x0127	xxx	AV115	xxx	0	6	1	Thursday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode11	Min	4x0128	xxx	AV116	xxx	0	6	0	Friday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode12	Min	4x0129	xxx	AV117	xxx	0	6	2	Saturday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode13	Min	4x0130	xxx	AV118	xxx	0	6	1	Sunday: Second period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode14	Min	4x0131	xxx	AV119	xxx	0	6	1	Monday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode15	Min	4x0132	xxx	AV120	xxx	0	6	0	Tuesday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode16	Min	4x0133	xxx	AV121	xxx	0	6	2	Wednesday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode17	Min	4x0134	xxx	AV122	xxx	0	6	1	Thursday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode18	Min	4x0135	xxx	AV123	xxx	0	6	1	Friday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode19	Min	4x0136	xxx	AV124	xxx	0	6	2	Saturday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode20	Min	4x0137	xxx	AV125	xxx	0	6	2	Sunday: Third period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode21	Min	4x0138	xxx	AV126	xxx	0	6	1	Monday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode22	Min	4x0139	xxx	AV127	xxx	0	6	1	Tuesday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode23	Min	4x0140	xxx	AV128	xxx	0	6	0	Wednesday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode24	Min	4x0141	xxx	AV129	xxx	0	6	2	Thursday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode25	Min	4x0142	xxx	AV130	xxx	0	6	1	Friday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode26	Min	4x0143	xxx	AV131	xxx	0	6	1	Saturday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Week Schedule	Standard	TimeSw-Mode27	Min	4x0144	xxx	AV132	xxx	0	6	0	Sunday: Fourth period operating mode: 0=OFF, 1=low speed, 2=high speed, 6=medium speed
AHU controller	Control	Standard	TempRegMode		4x0148	xxx	AV133	xxx	0	3	0	0=supply, 1=Extract, 2=Room, 3=supply/extract differential
AHU controller	Set point	Standard	TempRegSet	°C	4x0149	xxx	AV134	xxx	0	4000		Temperature setpoint for actual control type [1/100°C]
AHU controller	Set point	Standard	SupTempMinSet	°C	4x0150	xxx	AV135	xxx	0	4000	1000	Min. limit supply temperature [1/100°C]
AHU controller	Set point	Standard	SupTempMaxSet	°C	4x0151	xxx	AV136	xxx	2000	5000	3500	Max. limit supply temperature [1/100°C]
AHU controller	Set point	Standard	SupTempDiffSet	°C	4x0152	xxx	AV137	xxx	100	1500	300	Setpoint: Temperature differential between supply and extract. Only relevant when TempRegMode is 3 (supply/extract differential) (constant supply/extract - differential temperature control) [1/100°C]
AHU controller	Alarm	Standard	SupTempDiffAir	°C	4x0155	xxx	NA	xxx	200	1500	500	Alarm limit for temperature differential between supply setpoint and actual value [1/100°C]
AHU controller	Alarm	Standard	SupTempDiffAir	°C	4x0156	xxx	AV138	xxx	200	1500	500	Alarm limit for temperature differential between supply setpoint and actual value [1/100°C]
Heating	Control	Standard	SupTempHeatPB	°C	4x0157	xxx	AV139	xxx	200	10000	750	P-band for supply air temperature control [1/100°C]
Cooling coil	Control	Standard	SupTempCool_IT	sec	4x0158	xxx	AV140	xxx	10	30000	700	I-time for supply cooling control [sec]
Heat exchanger	Control	Standard	SupTempExc_IT	sec	4x0159	xxx	AV141	xxx	10	30000	120	I-time for supply heat exchanger control [sec]
Heating	Control	Standard	SupTempHeat_IT	sec	4x0160	xxx	AV142	xxx	10	30000	300	I-time for supply heating control [sec]
Fan	Control	Standard	SupTempDnRegIt	sec	4x0161	xxx	AV143	xxx	10	30000	120	I-time for supply flow reduction in case of low supply temperature [sec]
Heater 2	Control	Standard	SupTempHeat2IT	sec	4x0162	xxx	NA	NA	10	30000	300	I-time for supply heating2 control [sec]
Heat pump	Control	Speciel	SupTempHP_IT	sec	4x0164	xxx	NA	NA	10	30000	300	I-time for heat pump[sec]
Heating	Control	Standard	ExtTempDiffAir	°C	4x0165	xxx	AV144	xxx	200	1500	500	Alarm limit for temperature differential between extract setpoint and actual value [1/100°C]
Heating	Control	Standard	ExtTempHeatPB	°C	4x0166	xxx	AV145	xxx	200	10000	500	P-band for extract air temperature control [1/100°C]
Cooling coil	Control	Standard	ExtTempCool_IT	sec	4x0167	xxx	AV146	xxx	10	30000	1000	I-time for extract cooling control [sec]
Heat exchanger	Control	Standard	ExtTempExc_IT	sec	4x0168	xxx	AV147	xxx	10	30000	300	I-time for extract heat exchanger control [sec]
Heating	Control	Standard	ExtTempHeat_IT	sec	4x0169	xxx	AV148	xxx	10	30000	600	I-time for extract heating control [sec]
Fan	Control	Standard	ExtTempDnRegIt	sec	4x0170	xxx	AV149	xxx	10	30000	300	I-time for extract flow reduction in case of low supply temperature [sec]
Heater 2	Control	Standard	ExtTempHeat2IT	sec	4x0171	xxx	NA	NA	10	30000	300	I-time for heating2 control [sec]
Heat pump	Control	Standard	ExtTempHP_IT	sec	4x0173	xxx	NA	NA	10	30000	600	I-time for heat pump control [sec]
AHU controller	Summer/Winter comp.	Standard	SWTC_WinX1	°C	4x0175	xxx	AV150	xxx	-3000	0	-1500	Summer/winter temp. comp.: low outdoor temp. setpoint, winter [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SWTC_WinX2	°C	4x0176	xxx	AV151	xxx	-1000	1000	0	Summer/winter temp. comp.: high outdoor temp. setpoint, winter [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SWTC_SumX1	°C	4x0177	xxx	AV152	xxx	1000	3000	2000	Summer/winter temp. comp.: low outdoor temp. setpoint, summer [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SWTC_SumX2	°C	4x0178	xxx	AV153	xxx	2000	4000	3000	Summer/winter temp. comp.: high outdoor temp. setpoint, summer [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SWTCWinComVal	°C	4x0179	xxx	AV154	xxx	0	10000	500	Summer/winter temp. comp.: winter compensation [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SWTCSumComVal	°C	4x0180	xxx	AV155	xxx	-1000	1000	-500	Summer/winter temp. comp.: summer compensation [1/100°C]
Cooling coil	Alarm	Standard	C_LoPress1Alr	Bar	4x0181	6.41	AV315	6.41	0	10000	300	LoPressSens-1 AlarmLimit [1/100 Bar]
Cooling coil	Alarm	Standard	C_HIPress1Alr	Bar	4x0182	6.41	AV316	6.41	0	10000	1500	HiPressSens-1 AlarmLimit [1/100 Bar]
Cooling coil	Alarm	Standard	C_LoPress2Alr	Bar	4x0183	6.41	AV317	6.41	0	10000	300	LoPressSens-2 AlarmLimit [1/100 Bar]
Cooling coil	Alarm	Standard	C_HIPress2Alr	Bar	4x0184	6.41	AV318	6.41	0	10000	1500	HiPressSens-2 AlarmLimit [1/100 Bar]

AHU controller	Summer/Winter comp.	Standard	SW_Mode	4x0185	x.xx	AV156	x.xx	0	4	Summer/winter changeover: 0=OFF (no summer/winter changeover) 1=Changeover determined by outdoor temperature 2=Changeover determined by date 3=Manual summer 4=Manual winter
AHU controller	Summer/Winter comp.	Standard	SW_OutWinterON	4x0186	x.xx	AV157	x.xx	-3000	4000	0 Outdoor temperature for start of winter operation (SW_Mode = 1) [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SW_OutSummerON	4x0187	x.xx	AV158	x.xx	-3000	4000	2000 Outdoor temperature for start of summer operation (SW_Mode = 1) [1/100°C]
AHU controller	Summer/Winter comp.	Standard	SW_MonthWinON	4x0188	x.xx	AV159	x.xx	7	12	11 Month for start of winter operation (SW_Mode = 2)
AHU controller	Summer/Winter comp.	Standard	SW_DateWinON	4x0189	x.xx	AV160	x.xx	1	31	1 Date for start of winter operation (SW_Mode = 2)
AHU controller	Summer/Winter comp.	Standard	SW_MonthSumON	4x0190	x.xx	AV161	x.xx	1	6	5 Month for start of summer operation (SW_Mode = 2)
AHU controller	Summer/Winter comp.	Standard	SW_DateSumON	4x0191	x.xx	AV162	x.xx	1	31	1 Date for start of summer operation (SW_Mode = 2)
Damper, Recirculation	Set point	Standard	RecircStartTmp	4x0195	x.xx	AV163	x.xx	500	4000	1900 Startup temperature for recirculation [1/100 °C]
Damper, Recirculation	Set point	Standard	RecircStopTmp	4x0196	x.xx	AV164	x.xx	500	4000	2100 Stop temperature for recirculation [1/100 °C]
Damper, Recirculation	Set point	Special	RecircStartTmp2	4x0197	x.xx	AV165	x.xx	500	4000	2100 Start temperature for recirculation [1/100 °C]
Damper, Recirculation	Set point	Special	RecircStopTmp2	4x0198	x.xx	AV166	x.xx	500	4000	2100 Stop temperature for recirculation [1/100 °C]
Damper, Recirculation	Set point	Special	RecSwitchTmp2	4x0199	x.xx	AV167	x.xx	500	4000	2100 Switch temperature for recirculation [1/100 °C]
AHU controller	Fire	Standard	SupTempFireAir	4x0200	x.xx	AV165	x.xx	5000	12000	8000 Setpoint for internal fire alarm in supply duct [1/100°C]
AHU controller	Fire	Standard	ExtTempFireAir	4x0201	x.xx	AV166	x.xx	3500	12000	7000 Setpoint for internal fire alarm in extract duct [1/100°C]
Cooling coil	Control	Standard	CoolFanForcePc	4x0205	x.xx	AV167	x.xx	0	10000	2500 Increase in fan speed when cooling is active [%]
Cooling coil	Set point	Standard	CoolOutTmpMin	4x0206	x.xx	AV168	x.xx	0	3000	1500 Min. outdoor temperature for start of cooling
Cooling coil	Set point	Standard	CoolSupMinTmp	4x0207	x.xx	AV169	x.xx	0	2500	1200 Min. supply temperature when cooling is active (only with room temp. control)
AHU controller	Summer Night Cooling	Standard	SN_ExtTmpStart	4x0210	x.xx	AV170	x.xx	1500	4000	2300 Summer night extract/room temp. start [1/100°C]
AHU controller	Summer Night Cooling	Standard	SN_ExtTmpStop	4x0211	x.xx	AV171	x.xx	1000	3000	2000 Summer night extract/room temp. stop [1/100°C]
AHU controller	Summer Night Cooling	Standard	SN_OutTmpStart	4x0212	x.xx	AV172	x.xx	500	2000	1200 Summer night outdoor temp. start [1/100°C]
AHU controller	Summer Night Cooling	Standard	SN_SupTmpSet	4x0213	x.xx	AV173	x.xx	500	2000	1000 Summer night supply temp. control setpoint [1/100°C]
AHU controller	Summer Night Cooling	Standard	SN_StartTime	4x0214	x.xx	AV174	x.xx	0	1439	1380 Summer night start [min]
AHU controller	Summer Night Cooling	Standard	SN_StopTime	4x0215	x.xx	AV175	x.xx	0	1439	360 Summer night stop [min]
Heat exchanger	Set point	Special	CExcDelceTemp	4x0220	x.xx	AV176	x.xx	-500	2000	500 Min. exhaust temp setpoint for cross-flow heat exchanger [1/100°C]
Heat exchanger	Set point	Special	CExcDelceTempP	4x0221	x.xx	AV177	x.xx	200	2000	500 P-band for bypass control of cross-flow heat exchanger [1/100°C]
Heat exchanger	Set point	Special	CExcDelcePress	4x0222	x.xx	AV313	6.41	10	5000	30 Setpoint for pressure drop across cross-flow exchanger for start of de-icing [Pa]
Heat exchanger	Control	Special	CExcDelceTime	4x0223	x.xx	AV314	6.41	180	1800	300 Setpoint for duration of heat exchanger de-icing [sec] Circulation pump mode on heat exchanger coil: 1 0 -> Pump runs constantly 1 -> Pump runs if heat recovery demand is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. is < temp. setpoint for pump start Startup temp. setpoint for circulation pump on heat exchanger coil 1500 ONLY used if CoilExc_PumpFunc (Address 224) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Temp. differential alarm setpoint for heat exchanger coil 800 Alarm activated if temperature differential (in relation to outdoor temp.) downstream from heat exchanger coil operating at 50% power (or more) is lower than the alarm setpoint
Heat exchanger	Control	Standard	BattEXC_PumpFc	4x0225	x.xx	AV178	x.xx	0	3	1 0 -> Pump runs constantly 1 -> Pump runs if heat recovery demand is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. is < temp. setpoint for pump start Startup temp. setpoint for circulation pump on heat exchanger coil 1500 ONLY used if CoilExc_PumpFunc (Address 224) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Temp. differential alarm setpoint for heat exchanger coil 800 Alarm activated if temperature differential (in relation to outdoor temp.) downstream from heat exchanger coil operating at 50% power (or more) is lower than the alarm setpoint
Heat exchanger	Control	Standard	BattEXC_PumpSt	4x0226	x.xx	AV179	x.xx	0	4000	1500 ONLY used if CoilExc_PumpFunc (Address 224) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Temp. differential alarm setpoint for heat exchanger coil 800 Alarm activated if temperature differential (in relation to outdoor temp.) downstream from heat exchanger coil operating at 50% power (or more) is lower than the alarm setpoint
Heat exchanger	Alarm	Standard	BattEXC_AlrSet	4x0227	x.xx	AV180	x.xx	-1000	2000	800 Alarm activated if temperature differential (in relation to outdoor temp.) downstream from heat exchanger coil operating at 50% power (or more) is lower than the alarm setpoint
Humidity	Set point	Standard	Humid_SupSet	4x0228	x.xx	AV304	6.12	0	10000	2000 Humidity setpoint for selected control type (supply/exhaust) [1/100%] RH
Heating coil 1, Water	Set point	Standard	HW1UpStartPow	4x0230	x.xx	AV181	x.xx	0	10000	5000 Heating coil: Startup power setpoint [1/100%] Circulation pump mode on heating coil: 1 0 -> Pump runs constantly 1 -> Pump runs if heat demand is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. is < temp. setpoint for pump start Startup temp. setpoint for circulation pump on heating coil 1500 ONLY used if HW_PumpFunc (Address 230) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Temp. setpoint for start of heating coil 2500 Setpoint for frost protection control when unit is in STOP mode [1/100°C] 500 Setpoint for frost prot. control when unit is in OPERATING mode [1/100°C] 500 Setpoint for frost protection control [1/100°C] 200 Setpoint for frost protection temp. alarm [1/100°C]
Heating coil 1, Water	Control	Standard	HW1PumpFunc	4x0231	x.xx	AV182	x.xx	0	3	1 0 -> Pump runs constantly 1 -> Pump runs if heat demand is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. is < temp. setpoint for pump start Startup temp. setpoint for circulation pump on heating coil 1500 ONLY used if HW_PumpFunc (Address 230) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Temp. setpoint for start of heating coil 2500 Setpoint for frost protection control when unit is in STOP mode [1/100°C] 500 Setpoint for frost prot. control when unit is in OPERATING mode [1/100°C] 500 Setpoint for frost protection control [1/100°C] 200 Setpoint for frost protection temp. alarm [1/100°C]
Heating coil 1, Water	Set point	Standard	HW1FrzStartTmp	4x0232	x.xx	AV183	x.xx	500	3000	1500 ONLY used if HW_PumpFunc (Address 230) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Temp. setpoint for start of heating coil 2500 Setpoint for frost protection control when unit is in STOP mode [1/100°C] 500 Setpoint for frost prot. control when unit is in OPERATING mode [1/100°C] 500 Setpoint for frost protection control [1/100°C] 200 Setpoint for frost protection temp. alarm [1/100°C]
Heating coil 1, Water	Set point	Standard	HW1FrzStopSet	4x0233	x.xx	AV184	x.xx	500	4000	2500 Setpoint for frost protection control when unit is in STOP mode [1/100°C]
Heating coil 1, Water	Set point	Standard	HW1FrzDriftSet	4x0234	x.xx	AV185	x.xx	200	2000	500 Setpoint for frost protection control [1/100°C]
Heating coil 1, Water	Control	Standard	HW1FrzPB	4x0235	x.xx	AV186	x.xx	200	2000	200 Setpoint for frost protection temp. alarm [1/100°C]
Heating coil 1, Water	Set point	Standard	HW1FrzAlrTpSet	4x0236	x.xx	AV187	x.xx	200	2000	200 Setpoint for frost protection temp. alarm [1/100°C] Heating coil 1 300 Start circulation pump with %-open valve [1/100%] ONLY used if HW1_PumpFunc (Address 230) = 1 The pump starts when the value is exceeded. Cooling water pump mode: 0 0 -> Pump runs constantly 1 -> Pump runs if cooling power is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. > temp. setpoint for pump start Temp. setpoint for start of cooling coil pump 2100 ONLY used if CW_PumpFunc (Address 239) = 2 Pump runs if outdoor temp. is > temp. setpoint for pump start External signal GreenZone, supply [1/100%] External signal GreenZone, exhaust [1/100%] 80 Alarm limit for pressure drop across intake filter (static mode) 80 Alarm limit for pressure drop across exhaust filter (static mode) 5000 Alarm limit for pressure drop across intake filter (dynamic mode) 5000 Alarm limit for pressure drop across exhaust filter (dynamic mode) 80 Filter Pressure Air Limit for SupFilter2 (static mode) Alarm email setup 0 -> Emails not sent 3 1 -> Emails sent for A-alarms 2 -> Emails sent for B-alarms 3 -> Emails sent for A and B-alarms User RE (B-Alarm relay) Function: 0 -> B-alarm
Heating coil 1, Water	Set point	Standard	HW1PmpStartPrc	4x0237	x.xx	AV312	6.41	0	10000	300 Start circulation pump with %-open valve [1/100%] ONLY used if HW1_PumpFunc (Address 230) = 1 The pump starts when the value is exceeded. Cooling water pump mode: 0 0 -> Pump runs constantly 1 -> Pump runs if cooling power is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. > temp. setpoint for pump start Temp. setpoint for start of cooling coil pump 2100 ONLY used if CW_PumpFunc (Address 239) = 2 Pump runs if outdoor temp. is > temp. setpoint for pump start External signal GreenZone, supply [1/100%] External signal GreenZone, exhaust [1/100%] 80 Alarm limit for pressure drop across intake filter (static mode) 80 Alarm limit for pressure drop across exhaust filter (static mode) 5000 Alarm limit for pressure drop across intake filter (dynamic mode) 5000 Alarm limit for pressure drop across exhaust filter (dynamic mode) 80 Filter Pressure Air Limit for SupFilter2 (static mode) Alarm email setup 0 -> Emails not sent 3 1 -> Emails sent for A-alarms 2 -> Emails sent for B-alarms 3 -> Emails sent for A and B-alarms User RE (B-Alarm relay) Function: 0 -> B-alarm
Cooling coil	Control	Standard	CW_PumpFunc	4x0240	x.xx	AV188	x.xx	0	3	0 0 -> Pump runs constantly 1 -> Pump runs if cooling power is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. > temp. setpoint for pump start Temp. setpoint for start of cooling coil pump 2100 ONLY used if CW_PumpFunc (Address 239) = 2 Pump runs if outdoor temp. is > temp. setpoint for pump start External signal GreenZone, supply [1/100%] External signal GreenZone, exhaust [1/100%] 80 Alarm limit for pressure drop across intake filter (static mode) 80 Alarm limit for pressure drop across exhaust filter (static mode) 5000 Alarm limit for pressure drop across intake filter (dynamic mode) 5000 Alarm limit for pressure drop across exhaust filter (dynamic mode) 80 Filter Pressure Air Limit for SupFilter2 (static mode) Alarm email setup 0 -> Emails not sent 3 1 -> Emails sent for A-alarms 2 -> Emails sent for B-alarms 3 -> Emails sent for A and B-alarms User RE (B-Alarm relay) Function: 0 -> B-alarm
Cooling coil	Set point	Standard	CW_PmpStartTmp	4x0241	x.xx	AV189	x.xx	500	4000	2100 ONLY used if CW_PumpFunc (Address 239) = 2 Pump runs if outdoor temp. is > temp. setpoint for pump start External signal GreenZone, supply [1/100%] External signal GreenZone, exhaust [1/100%] 80 Alarm limit for pressure drop across intake filter (static mode) 80 Alarm limit for pressure drop across exhaust filter (static mode) 5000 Alarm limit for pressure drop across intake filter (dynamic mode) 5000 Alarm limit for pressure drop across exhaust filter (dynamic mode) 80 Filter Pressure Air Limit for SupFilter2 (static mode) Alarm email setup 0 -> Emails not sent 3 1 -> Emails sent for A-alarms 2 -> Emails sent for B-alarms 3 -> Emails sent for A and B-alarms User RE (B-Alarm relay) Function: 0 -> B-alarm
GreenZone	Set point	Standard	FanOptSupExtIn	4x0242	x.xx	AV223	x.xx	0	10000	External signal GreenZone, supply [1/100%]
GreenZone	Set point	Standard	FanOptExtExtIn	4x0243	x.xx	AV224	x.xx	0	10000	External signal GreenZone, exhaust [1/100%]
Filter	Alarm	Standard	FltSupStatAlr	4x0245	x.xx	AV190	x.xx	10	500	80 Alarm limit for pressure drop across intake filter (static mode)
Filter	Alarm	Standard	FltExtStatAlr	4x0246	x.xx	AV191	x.xx	10	500	80 Alarm limit for pressure drop across exhaust filter (static mode)
Filter	Alarm	Standard	FltSupDynAlr	4x0247	x.xx	AV192	x.xx	1000	10000	5000 Alarm limit for pressure drop across intake filter (dynamic mode)
Filter	Alarm	Standard	FltExtDynAlr	4x0248	x.xx	AV193	x.xx	1000	10000	5000 Alarm limit for pressure drop across exhaust filter (dynamic mode)
Filter	Alarm	Standard	FltSup2StaAlr	4x0249	4.18	AV258	4.18	10	500	80 Filter Pressure Air Limit for SupFilter2 (static mode) Alarm email setup 0 -> Emails not sent 3 1 -> Emails sent for A-alarms 2 -> Emails sent for B-alarms 3 -> Emails sent for A and B-alarms User RE (B-Alarm relay) Function: 0 -> B-alarm
AHU controller	Alarm	Standard	Alr_MailSetup	4x0250	x.xx	AV194	x.xx	0	3	0 -> Emails not sent 3 1 -> Emails sent for A-alarms 2 -> Emails sent for B-alarms 3 -> Emails sent for A and B-alarms User RE (B-Alarm relay) Function: 0 -> B-alarm
AHU controller	Alarm	Standard	UserRE_Func	4x0251	x.xx	AV195	x.xx	0	4	0 -> Low speed indication 2 -> High speed indication 3 -> Medium speed indication
Preheater coil	Set point	Standard	PHStartPrc	4x0252	x.xx	AV206	x.xx	0	30000	5000 Pre-heating coil - Start-up output setpoint [1/100%]; when system is in start-up sequence Pre-heating coil Circulation pump function: 0 0 -> Pump runs constantly 1 -> Pump runs if heat output is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. is > temp. setpoint for pump start Pre-heating coil Start temperature for circulation pump of pre-heating coil. ONLY used if PHPumpMode (Address 252) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start
Preheater coil	Control	Standard	PHPumpMode	4x0253	x.xx	AV210	x.xx	0	4	0 0 -> Pump runs constantly 1 -> Pump runs if heat output is > 0 (AutoMode) 2 -> Pump runs if outdoor temp. is > temp. setpoint for pump start Pre-heating coil Start temperature for circulation pump of pre-heating coil. ONLY used if PHPumpMode (Address 252) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start
Preheater coil	Set point	Standard	PHPmpSTmpH	4x0254	x.xx	AV208	x.xx	500	3000	1000 Pre-heating coil Start temperature for circulation pump of pre-heating coil. ONLY used if PHPumpMode (Address 252) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start
Preheater coil	Set point	Standard	PHStandbyTmp	4x0255	x.xx	AV205	x.xx	500	4000	2500 Pre-heating coil Setpoint for frost protection control when system is in STOP mode [1/100°C]
Preheater coil	Set point	Standard	PHFrzDrSetH	4x0256	x.xx	AV209	x.xx	200	2000	500 Pre-heating coil Setpoint for frost protection control when system is in OPERATING mode [1/100°C]
Preheater coil	Control	Standard	PHHeatFrzPB	4x0257	x.xx	AV207	x.xx	200	2000	500 Pre-heating coil P-band for frost protection control [1/100°C]

Preheater coil	Alarm	Standard	PHMinAirFrz	°C	4x0258	x.xx	AV204	x.xxx	-4000	10000	200	Pre-heating coil - Frost alarm
Preheater coil	Set point	Standard	PHeatSet	°C	4x0259	x.xxx	AV203	x.xxx	-3000	2000	200	Setpoint for frost protection temperature alarm [1/100°C]
Heating coil 2, Water	Set point	Standard	HW2UpStartPow	%	4x0260	x.xxx	AV196	x.xxx	0	10000	5000	Pre-heating coil - Setpoint supply duct; just after pre-heating coil Heating coil 2 - Start-up output setpoint [1/100%]
Heating coil 2, Water	Control	Standard	HW2PumpFunc		4x0261	x.xxx	AV197	x.xxx	0	3		Heating coil 2 Circulation pump function: 1 0 -> Pump runs constantly 1 -> Pump runs if heating valve %-open is > value set in address = 262 2 -> Pump runs if outdoor temp. is > temp. setpoint for pump start (address = 261)
Heating coil 2, Water	Set point	Standard	HW2PmpStartTmp	°C	4x0262	x.xxx	AV198	x.xxx	500	3000	1500	Start temperature for circulation pump of heating coil 2 ONLY used if WaterPumpFunc (Address 260) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start Heating coil 2 - Start circulation pump with %-open valve. ONLY used if HW2_PumpFunc (Address 260) = 1 The pump starts when the value is exceeded.
Heating coil 2, Water	Set point	Standard	HW2PmpStartPrc	%	4x0263	x.xxx	AV311	6.41	0	10000	300	ONLY used if HW2_PumpFunc (Address 260) = 1 The pump starts when the value is exceeded.
Heating coil 2, Water	Set point	Standard	HW2FrzStopSet	°C	4x0264	x.xxx	AV199	x.xxx	500	4000	2500	Heating coil 2 - Setpoint for frost protection control when unit is in STOP mode [1/100°C]
Heating coil 2, Water	Set point	Standard	HW2FrzDriftSet	°C	4x0265	x.xxx	AV200	x.xxx	200	2000	500	Heating coil 2 - Setpoint for frost protection control when unit is in OPERATING mode [1/100°C]
Heating coil 2, Water	Control	Standard	HW2FreezePB	°C	4x0266	x.xxx	AV201	x.xxx	200	2000	500	Heating coil 2 - P-band for frost protection control [1/100°C]
Heating coil 2, Water	Alarm	Standard	HW2FrzAirTpSet	°C	4x0267	x.xxx	AV202	x.xxx	200	2000	200	Heating coil 2 - Setpoint for frost protection temperature alarm [1/100°C]
Cooling coil	Set point	Standard	CW_PumpStartPr	%	4x0268	x.xxx	AV310	6.41	0	10000	2500	Cooling coil (hydraulic cooling) - Start circulation pump with %-open valve ONLY used if CW_PumpFunc (Address 239) = 1. The pump starts when the value is exceeded.
Heat exchanger	Set point	Standard	BattEXCpmpSPr	%	4x0269	x.xxx	AV309	6.41	0	10000	2500	Heat exchange coil - Start circulation pump with %-open valve. ONLY used if CoilEXC_PumpFc (Address 224) = 1. The pump starts when the value is exceeded.
Heat pump	Set point	Special	HP_MinOpTemp1	°C	4x0270	x.xxx	AV215	x.xxx	-4000	4000	1000	Min. outdoor temperature for activating heat pump relay no. 1
Heat pump	Set point	Special	HP_MinOpTemp2	°C	4x0271	x.xxx	AV216	x.xxx	-4000	4000	1000	Min. outdoor temperature for activating heat pump relay no. 2
Heat pump	Set point	Special	HP_MinOpTemp3	°C	4x0272	x.xxx	AV217	x.xxx	-4000	4000	1000	Min. outdoor temperature for activating heat pump relay no. 3
Heat pump	Set point	Special	HP_MinOpTemp4	°C	4x0273	x.xxx	AV218	x.xxx	-4000	4000	1000	Min. outdoor temperature for activating heat pump relay no. 4
Combi coil	Set point	Standard	CombiUpStIPow	%	4x0275	x.xxx	AV286	4.22	0	10000	5000	Combi coil - Start-up output setpoint [1/100%]
Combi coil	Control	Standard	CombiPumpFunc		4x0276	x.xxx	AV287	4.22	0	3		Combi coil Circulation pump function: 1 0 -> Pump runs constantly 1 -> Pump runs if valve %-open is > value set in address = 277 2 -> Pump runs if outdoor temp. is > temp. setpoint for pump start (address = 276)
Combi coil	Set point	Standard	CombiPmpSTmpH	°C	4x0277	x.xxx	AV288	4.22	500	3000	1000	Start temperature for circulation pump of Combi coil ONLY used if CombiPumpFunc (Address 275) = 2 Pump runs if outdoor temp. is < temp. setpoint for pump start
Combi coil	Set point	Standard	CombiPmpStPrc	%	4x0278	x.xxx	AV289	4.22	0	10000	300	Combi coil - Start circulation pump with %-open valve ONLY used if CombiPumpFunc (Address 275) = 1 The pump starts when the value is exceeded.
Combi coil	Set point	Standard	CombFrzStopSet	°C	4x0279	x.xxx	AV290	4.22	500	4000	2500	Combi coil - Setpoint for frost protection control when system is in Stop mode [1/100°C]
Combi coil	Set point	Standard	CombFrzDrSetH	°C	4x0280	x.xxx	AV291	4.22	200	2000	500	Combi coil - Setpoint for frost protection control when system is in Operating mode [1/100°C]
Combi coil	Control	Standard	CombiFrzPB	°C	4x0281	x.xxx	AV292	4.22	200	2000	500	Combi coil - P-band for frost protection control [1/100°C]
Combi coil	Set point	Standard	CombiFrzAirSet	°C	4x0282	x.xxx	AV293	4.22	200	2000	200	Combi coil - Setpoint for frost protection temperature alarm [1/100°C]
Heat exchanger	Set point	Standard	BattEXCFCrzStop	°C	4x0283	x.xxx	AV219	x.xxx	-1000	4000	2500	Fluid-coupled coil - Setpoint for frost protection control when unit is in STOP mode [1/100°C]
Heat exchanger	Set point	Standard	BattEXCFCrzDrf	°C	4x0284	x.xxx	AV220	x.xxx	-1000	2000	500	Fluid-coupled coil - Setpoint for frost protection control when unit is in OPERATING mode [1/100°C]
Heat exchanger	Control	Standard	BattEXCFCrzPB	°C	4x0285	x.xxx	AV221	x.xxx	200	2000	500	Fluid-coupled coil - P-band for frost protection control [1/100°C]
Heat exchanger	Set point	Standard	BattEXCFCrzASet	°C	4x0286	x.xxx	AV222	x.xxx	-1000	2000	200	Fluid-coupled coil - Setpoint for frost protection temperature alarm [1/100°C]
Combi coil	Current value	Standard	CombiBattTemp	°C	4x0287	x.xxx	NA	NA	-4000	10000		Combi coil - Actual return temperature [1/100°C]
Heating coil, Water	Control	Special	HW12_VDCCoFunc		4x0288	x.xxx	AV225	x.xxx	0	1	0	Only special customer code: Heat coil 1, step2 output (Out.1,2): Valve actuator type 0->0-10V, 1->2-10V
Heating coil 12	Set point	Special	HW12_VDCCoFunc	mV	4x0289	x.xxx	NA	NA	0	10000		Only special customer code: Heat coil 1, step2 output (1,2) VDC out
Heating coil 12	Set point	Special	H2LimTyp	%	4x0290	x.xxx	AV229	x.xxx	0	2	0	Only special customer code: Heat2 limiting type 1Room, 2 Outdoor
Heating coil 12	Set point	Special	H2SLimRTemp	°C	4x0291	x.xxx	AV230	x.xxx	-500	0	-200	Only special customer code: Start/difference temperature [1/100°C]
Heating coil 12	Set point	Special	H2SLimRPer	%	4x0292	x.xxx	AV231	x.xxx	1000	10000	2000	Only special customer code: Stepsize limiting roomtemp [1/100%]
Heating coil 12	Set point	Special	H2SLimOTemp	°C	4x0293	x.xxx	AV232	x.xxx	-2000	2000	-50	Only special customer code: Blocking of Heat2 Outdoor temp [1/100°C]
Heating coil 12	Set point	Special	H2SetDelTime	Sec	4x0294	x.xxx	AV234	x.xxx	0	7200	3600	Only special customer code: Timeset delayed Heat 2 [Sec]
Heating coil 12	Set point	Special	H2FlowOffset	%	4x0295	x.xxx	AV233	x.xxx	-5000	5000	5000	Only special customer code: in % of Flow if Heat2 is on [1/100%]
Cooling coil	Set point	Special	NO_CSStopRTemp	°C	4x0296	x.xxx	AV228	x.xxx	0	3000	2300	Only special customer code: Stop cooling over roomtemperature [1/100°C]
Cooling coil	Set point	Special	REXDelcePerc	%	4x0297	x.xxx	AV226	x.xxx	3000	10000	5000	Only special customer code: Pressure percent over calibration
Cooling coil	Set point	Special	NO_FAirCoolBlik	°C	4x0298	x.xxx	AV227	x.xxx	-4000	2000	1000	Only special customer code: Stop temperature fresh air cooling [1/100°C]
Humidity	Set point	Standard	DehumSet_RH	ppm	4x0299	x.xxx	AV250	x.xxx	1000	10000	7000	Set point %RH dehumidification [1/100%]
Damper, Recirculation	Control	Special	RecFlowShift		4x0300	x.xxx	AV235	x.xxx	0	2	0	Only special customer code: Set Change Airflow Recirc
Damper, Recirculation	Set point	Special	RecClosDSSTemp	°C	4x0301	x.xxx	AV236	x.xxx	-1000	2000	0	Only special customer code: Temperature for start with open damper [1/100°C]
Damper, Recirculation	Alarm	Special	REXAirLPrCfrz	%	4x0302	x.xxx	AV308	6.41	0	20000	12000	Only special customer code: Alarmlevel in percent if frozen [1/100%]
Damper, Recirculation	Alarm	Special	REXAirLPrCDus	%	4x0303	x.xxx	AV307	6.41	0	10000	2000	Only special customer code: Alarmlevel in percent, if dusty [1/100%]
AHU controller	Set point	Special	NightSetback	°C	4x0313	6.51	AV306	6.41	0	2000	0	Only special customer code: Night setback [1/100°C]
Heating coil, Water	Control	Special	HW1RiseT100	Sec	4x0304	x.xxx	AV305	NA	120	7200	3600	Only special customer code: RiseTime 0..100%, in sec [Sec]
Cooling, DX	Set point	Special	ROHRiseT100	Sec	4x0305	x.xxx	AV237	x.xxx	120	7200	3600	Only special customer code: Timeset for CO2 DX-Cooling-Aggregate from 0..100% [Sec]
AHU controller	Summer Night Cooling	Standard	SNSUpCoolFlw	l/s	4x0306	x.xxx	AV238	x.xxx	0	32000	2000	Setpoint supply air volume sommernight cooling
AHU controller	Summer Night Cooling	Standard	SNSExCoolFlw	l/s	4x0307	x.xxx	AV239	x.xxx	0	32000	2000	Setpoint extract air volume sommernight cooling [m3/h]
AHU controller	Summer Night Cooling	Standard	SNSUpCoolPa	Pa	4x0308	x.xxx	AV240	x.xxx	0	5000	50	Setpoint supply air pressure sommernight cooling [Pa]
AHU controller	Summer Night Cooling	Standard	SNSExCoolPa	Pa	4x0309	x.xxx	AV241	x.xxx	0	5000	50	Setpoint extract air pressure sommernight cooling [Pa]
AHU controller	Summer Night Cooling	Standard	SNSUpCoolPrc	%	4x0310	x.xxx	AV242	x.xxx	0	10000	2000	Setpoint supply air constant speed sommernight cooling [1/100%]
AHU controller	Summer Night Cooling	Standard	SNSExCoolPrc	%	4x0311	x.xxx	AV243	x.xxx	0	10000	2000	Setpoint extract air constant speed sommernight cooling [1/100%]
AHU controller	Summer Night Cooling	Standard	SNSlVOffsPrc	%	4x0312	x.xxx	AV247	x.xxx	-5000	5000	0	Sommernight cooling slave offset [1/100%]
CO2 sensor	Set point	Standard	DewCoolPower	%	4x0313	5.07	AV294	5.07	0	10000	1000	Max % CoolPower for Dehumidify without DewPointSensor
CO2 sensor	Set point	Special	CO2_MaxModRec	ppm	4x0314	x.xxx	AV246	x.xxx	0	10000	1000	Only special customer code: Max CO2 (Store mode) [ppm]
CO2 sensor	Set point	Special	CO2_MinModRec	ppm	4x0315	x.xxx	AV249	x.xxx	0	10000	1000	Only special customer code: Min CO2 (Store mode) [ppm]
Fan	Set point	Standard	SupMedSpeedSet	l/s	4x0320	x.xxx	AV251	x.xxx	0	30000	5000	Setpoint supply air flow - medium speed [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Fan	Set point	Standard	ExtMedSpeedSet	l/s	4x0321	x.xxx	AV254	x.xxx	0	30000	5000	Setpoint exhaust air flow - medium speed [l/s] or [m3/h] or [CFM] (Depending on the unit selection in the OJ-Air2Master)
Pressure	Set point	Standard	SupDuctPaMeSet	Pa	4x0322	x.xxx	AV252	x.xxx	0	5000	120	Setpoint supply air duct pressure medium speed [Pa]
Pressure	Set point	Standard	ExDuctPaMeSet	Pa	4x0323	x.xxx	AV255	x.xxx	0	5000	120	Setpoint exhaust air duct pressure medium speed [Pa]
CO2 sensor	Set point	Standard	CO2_UserSetMP	ppm	4x0324	x.xxx	AV256	x.xxx	0	10000	1000	CO2 controller setpoint medium speed (HI CO2 Val) [ppm]
Damper, Recirculation	Set point	Standard	RecMinFresh	%	4x0325	x.xxx	AV257	x.xxx	0	10000	1000	Setpoint minimum fresh air; Only if modulated recirculation is selected [1/100%]
Filter	Alarm	Standard	FiREx2StaAir	Pa	4x0326	4.18	AV259	4.18	10	500	80	Filter Pressure Air Limit for ExdFilter2 (static mode)
Filter	Alarm	Standard	FiREx2DinAir	%	4x0327	4.18	AV260	4.18	1000	10000	5000	Filter Pressure Air Limit for SupFilter (dynamic mode)
Filter	Alarm	Standard	FiREx2DinAir	%	4x0328	4.18	AV261	4.18	1000	10000	5000	Filter Pressure Air Limit for ExdFilter (dynamic mode)
Zone 1	Set point	Standard	ZM1_RoomTmpSet		4x0329	4.19	AV262	4.19	-4000	10000		ZoneModule 1 - Room Temperature Setpoint
Zone 1	Set point	Standard	ZM1_MinSupTemp		4x0330	4.19	AV263	4.19	-4000	10000		ZoneModule 1 - Minimum Supply Temperature
Zone 1	Set point	Standard	ZM1_MaxSupTemp		4x0331	4.19	AV264	4.19	-4000	10000		ZoneModule 1 - Maximum Supply Temperature
Zone 1	Set point	Standard	ZM1_CO2Set		4x0332	4.19	AV265	4.19	0	5000		ZoneModule 1 - Room CO2 Setpoint
Zone 1	Set point	Standard	ZM1_RHSet		4x0333	4.19	AV266	4.19	0	10000		ZoneModule 1 - Room RH Setpoint
Zone 1	Set point	Standard	ZM1_PIRMinFlow		4x0334	4.19	AV267	4.19	0	0		ZoneModule 1 - VAV Supply PIR Min Air Flow
Zone 2	Set point	Standard	ZM2_RoomTmpSet		4x0335	4.19	AV268	4.19	-4000	10000		ZoneModule 2 - Room Temperature Setpoint
Zone 2	Set point	Standard	ZM2_MinSupTemp		4x0336	4.19	AV269	4.19	-4000	10000		ZoneModule 2 - Minimum Supply Temperature

Zone 2	Set point	Standard	ZM2_MaxSupTemp	4x0337	4.19	AV270	4.19	-4000	10000	ZoneModule 2 - Maximum Supply Temperature
Zone 2	Set point	Standard	ZM2_CO2Set	4x0338	4.19	AV271	4.19	0	5000	ZoneModule 2 - Room CO2 Setpoint
Zone 2	Set point	Standard	ZM2_RHSet	4x0339	4.19	AV272	4.19	0	10000	ZoneModule 2 - Room RH Setpoint
Zone 2	Set point	Standard	ZM2_PIRMinFlow	4x0340	4.19	AV273	4.19	0	0	ZoneModule 2 - VAV Supply PIR Min Air Flow
Zone 3	Set point	Standard	ZM3_RoomTempSet	4x0341	4.19	AV274	4.19	-4000	10000	ZoneModule 3 - Room Temperature Setpoint
Zone 3	Set point	Standard	ZM3_MinSupTemp	4x0342	4.19	AV275	4.19	-4000	10000	ZoneModule 3 - Minimum Supply Temperature
Zone 3	Set point	Standard	ZM3_MaxSupTemp	4x0343	4.19	AV276	4.19	-4000	10000	ZoneModule 3 - Maximum Supply Temperature
Zone 3	Set point	Standard	ZM3_CO2Set	4x0344	4.19	AV277	4.19	0	5000	ZoneModule 3 - Room CO2 Setpoint
Zone 3	Set point	Standard	ZM3_RHSet	4x0345	4.19	AV278	4.19	0	10000	ZoneModule 3 - Room RH Setpoint
Zone 3	Set point	Standard	ZM3_PIRMinFlow	4x0346	4.19	AV279	4.19	0	0	ZoneModule 3 - VAV Supply PIR Min Air Flow
Zone 4	Set point	Standard	ZM4_RoomTempSet	4x0347	4.19	AV280	4.19	-4000	10000	ZoneModule 4 - Room Temperature Setpoint
Zone 4	Set point	Standard	ZM4_MinSupTemp	4x0348	4.19	AV281	4.19	-4000	10000	ZoneModule 4 - Minimum Supply Temperature
Zone 4	Set point	Standard	ZM4_MaxSupTemp	4x0349	4.19	AV282	4.19	-4000	10000	ZoneModule 4 - Maximum Supply Temperature
Zone 4	Set point	Standard	ZM4_CO2Set	4x0350	4.19	AV283	4.19	0	5000	ZoneModule 4 - Room CO2 Setpoint
Zone 4	Set point	Standard	ZM4_RHSet	4x0351	4.19	AV284	4.19	0	10000	ZoneModule 4 - Room RH Setpoint
Zone 4	Set point	Standard	ZM4_PIRMinFlow	4x0352	4.19	AV285	4.19	0	0	ZoneModule 4 - VAV Supply PIR Min Air Flow
Fan	Set point	Standard	SupFixMePrcSet	4x0353	6.10	AV253	6.10	100	10000	3500 Supply Motor Mediumspeed [1/100%], Fixed Fan Speed
Fan	Set point	Standard	SupFixLoPrcSet	4x0354	6.10	AV299	6.10	100	10000	2500 Supply Motor Lowspeed [1/100%], Fixed Fan Speed
Fan	Set point	Standard	SupFixHiPrcSet	4x0355	6.10	AV300	6.10	100	10000	5000 Supply Motor Highspeed [1/100%], Fixed Fan Speed
Fan	Set point	Standard	ExtFixMePrcSet	4x0356	6.10	AV301	6.10	100	10000	3500 Extract Motor Mediumspeed [1/100%], Fixed Fan Speed
Fan	Set point	Standard	ExtFixLoPrcSet	4x0357	6.10	AV302	6.10	100	10000	2500 Extract Motor Lowspeed [1/100%], Fixed Fan Speed
Fan	Set point	Standard	ExtFixHiPrcSet	4x0358	6.10	AV303	6.10	100	10000	5000 Extract Motor Highspeed [1/100%], Fixed Fan Speed
Damper, Recirculation	Set point	Standard	RecMaxFresh	4x0359	6.10	AV304	6.10	3000	10000	10000 Max FreshAir part [1/100%]
AHU controller	Set point	Special	ROHOutBlkTmp	4x0360	6.41	AV319	6.41	-2000	5000	-500 Heat 2 blocked over this Temperatur (Special Cust. Code only)
AHU controller	Control	Standard	BMSDrCtrlReg	4x0500	x.xx	AV244	x.xx	0	1000	11 = BMS stop 105 = BMS low speed 210 = BMS high speed 211 = BMS sommer/night cooling 220 = BMS night heating mode (Recirculation) 414 = BMS medium speed
Temp. out door	Current value	Standard	MBT_OutDoor	4x0501	x.xx	AV245	x.xx	-6000	10000	BMS outdoor temperatur [1/100°C]
Temp. room	Current value	Standard	MBT_Room1	4x0502	x.xx	AV246	x.xx	-4000	10000	BMS room temperatur [1/100°C]